



**GULF STATES UTILITIES COMPANY**

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 409 838-8631

October 31, 1985

File No. G9.5

RBG- 22,523

Director of Nuclear Reactor Regulation  
Attention: Dr. W. R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Butler:

River Bend Station - Unit 1  
Docket No. 50-458

In response to your letter dated September 25, 1985, this weekly status report is being provided which identifies those license conditions and other commitments that have been completed during the previous week and cumulatively since issuance of the low power license. Attachment 1 is a cumulative listing of license conditions and Attachment 2 covers other important commitments that have been completed. Should you have any questions please contact W. J. Reed of my staff.

Sincerely,

J. E. Booker  
Manager-Engineering,  
Nuclear Fuels & Licensing  
River Bend Nuclear Group

JEB/PJR/LAE/lp

Attachments

cc: Mr. Robert Martin RIV  
Mr. Dwight Chamberlain SRI

8511110054 851031  
PDR ADOCK 05000458  
R PDR

## ATTACHMENT 1

October 31, 1985  
RBG- 22,523

COMPLETED LICENSE CONDITIONS

<u>License Condition No.</u>	<u>Description</u>	<u>Comments</u>
L/C (1)2.a	Modify operating procedures to monitor control room HVAC cooling water (DR-314).	GSU letter 9/26/85
L/C (1)2.f	Complete HVAC charcoal loading and testing.	GSU letter 9/26/85
L/C (1)3.a.ii	Fire-wrap control building electrical raceways.	GSU letter 9/26/85
L/C (1)2.b	Modify EOP relative to Limitorque operators (DR-280).	GSU letter 10/3/85
L/C (1)5.a	Fuel building sampling system.	GSU letter 10/3/85
L/C (1)7.a	Elgar fuse blocks (DR-287).	GSU letter 10/3/85
L/C (13)	Use advisors until operating staff experience requirements are met.	GSU letter 9/26/85
L/C 2.D	Exemption for operation up to five percent from GDC2-Seismic Qualification of two AOV's (IDFR*144 and 145).	GSU letter 10/3/85
L/C (1)1.a	Test off-gas system and off-gas vault refrigeration system.	GSU letter 10/10/85
L/C (1)3.a.i	Test CO2 fire protection for T/G.	GSU letter 10/10/85
L/C (1)3.c	Complete modifications/qualification of IDFR*AOV 144 and 145 (DR-193).	GSU letter 10/10/85
L/C (16) 3	Submit containment venting information.	GSU letter 10/10/85

ATTACHMENT 1

October 31, 1985  
RBG- 22523  
Page 2

<u>License Condition No.</u>	<u>Description</u>	<u>Comments</u>
L/C (1)2.c	Verify Plant's air flow Characteristics.	GSU letter 10/17/85
L/C (1)2.d	Place sample panels in service after testing and calibration.	GSU letter 10/17/85
L/C (1)3.e	Modifications to reduce maximum emergency service load for Division I and II diesel generators.	GSU letter 10/24/85
L/C (1)2.e	Testing of service water modifications and TDI diesel generator load reduction modifications.	
L/C (6)	Environmental qualification of electrical equipment.	
L/C (1)3.b	Testing of liquid, gaseous and solid radwaste systems.	

## ATTACHMENT 2

October 31, 1985  
RBG- 22,523

OTHER COMMITMENTS COMPLETED

<u>Reference</u>	<u>Description</u>	<u>Comments</u>
RBG-21093 5/24/85	Perform internal sample review of Seismic Qualification Documentation before 5% power.	GSU letter 10/3/85
RBG-21378 6/24/85	Replace existing Rosemount 1153 B devices used for suppression pool water level measurement with Rosemount 1154 devices before exceeding 5% power.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	QA check of implementing and procedural documents pertaining to maintenance and surveillance of diesels against TDI Owner's Group and PNL recommendations.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	Incorporate PNL recommendations into TDI maintenance and surveillance programs.	GSU letter 10/3/85
TECH SPEC 6.8.4.d	Program to assure detection and prevention of Asiatic Clams.	GSU letter 10/10/85
RBG-21767 8/5/85	Submit Rev. 3 to Offsite Dose Calculation Manual.	GSU letter 10/10/85
6/13/85 Item A.1	High energy line break detection and mitigation.	
6/13/85 Item A.2	Moderate energy line crack detection and mitigation.	
6/13/85 Item B.1	Containment atmospheric monitoring.	
6/13/85 Item B.10	Miscellaneous building floor drains.	