

Omaha Public Power District

P.O. Box 399 Hwy. 75 - North of Ft. Calhoun Fort Calhoun, NE 68023-0399
402/636-2000

February 10, 1993
LIC-93-0047

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

- References: 1. Docket No. 50-285
2. LER 91-007 Revision 00, from OPPD (W. G. Gates) to NRC (Document Control Desk) dated April 19, 1991 (LIC-91-0015L)
3. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated October 29, 1992 (LIC-92-325)

Gentlemen:

Subject: Licensee Event Report 91-007 Revision 01 for the Fort Calhoun Station

Please find attached Licensee Event Report 91-007 Revision 01 dated February 10, 1993. This revision provides supplemental information regarding the results of corrective actions including a detailed walkdown of motor control centers, resolution of the twenty-one coordination problems reported in LER 91-007 Revision 00, and completion of the Breaker/Fuse Coordination Study. Information is also provided regarding an additional inadequate coordination identified based on the walkdown data. This additional inadequate coordination had been corrected prior to discovery.

Revisions to the Abstract and Text are denoted by vertical lines in the right margin. This report is being submitted pursuant to 10 CFR 50.73(a)(2)(ii)(B). If you should have any questions, please contact me.

Sincerely,

W. G. Gates

W. G. Gates
Vice President

WGG/jrg

190120

Attachment

c: J. L. Milhoan, NRC Regional Administrator, Region IV
S. D. Bloom, NRC Project Manager
R. P. Mullikin, NRC Senior Resident Inspector
INPO Records Center

Test