



**Wisconsin  
Electric**  
POWER COMPANY

231 W. Michigan, P.O. Box 2066, Milwaukee, WI 53201

(414) 224-2345

VPNPD-93-028A

NRC-93-013A

\*\*\*REVISED LER\*\*\*

February 16, 1993

Document Control Desk  
U.S. NUCLEAR REGULATORY COMMISSION  
Mail Station P1-137  
Washington, DC 20555


Gentlemen:

DOCKETS 50-266 AND 50-301  
LICENSEE EVENT REPORT 93-001-00  
INOPERABILITY OF THE DEGRADED GRID VOLTAGE RELAYS  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 93-001-00 for Point Beach Nuclear Plant, Units 1 and 2. This report is being reissued and supersedes the report submitted on February 4, 1993. This report is being submitted in accordance with the requirements of 10 CFR 50.73(a)(2)(ii)(B), "Any event or condition that resulted in the condition of the nuclear plant, including its principal safety barriers, being seriously degraded, or that resulted in the nuclear power plant being in a condition that was outside the design basis of the plant." This report describes the discovery of the situation where the degraded grid voltage relay setpoints could be too low to provide adequate protection for all safety-related equipment.

Please contact us if there are any questions.

Sincerely,

  
Bob Link  
Vice President  
Nuclear Power 220093

CAC/jg

Enclosure

cc: NRC Regional Administrator, Region III  
NRC Resident Inspector

9302230083 930216  
PDR ADOCK 05000266  
S PDR

*TRD*  
*11*