

August 14, 1985

Docket No. 99900509/84-03

Stone and Webster Engineering Corporation
ATTN: Mr. R. B. Kelley
Vice President, Quality Assurance
Post Office Box 2325
Boston, Massachusetts 02107

Gentlemen:

Thank you for your letters of April 12, 1985 and May 10, 1985, in response to our letter dated March 13, 1985. We have reviewed your reply and find it responsive to the concerns raised in Notice of Nonconformance with respect to Item A. We will review the implementation of your corrective actions for Item A during a future inspection to determine that full compliance has been achieved and will be maintained.

Your response to Nonconformance B references a calculation which fully qualifies the finite-element analyses data. This calculation was not made available for review at the time of the inspection. EAP 5.25 requires that all aspects of Category I computer codes be qualified, including numerical results used as input data. We will review the calculation mentioned above during a future inspection as well as the findings concerning this Item B, as stated in the March 13, 1985 Notice of Nonconformance.

Sincerely,

ORIGINAL SIGNED BY:
GARY G. ZECH

Gary G. Zech, Chief
Vendor Program Branch
Division of Quality Assurance, Vendor
and Technical Training Center Programs
Office of Inspection and Enforcement

DISTRIBUTION:

OMB:IE:09
VPB Reading
DQAVT Reading
JWCraig
RMCIntyre

B508160039 B50814
PDR QA999 EECSWE
99900509 PDR

VPB: DQAVT
RMCIntyre:sam
8/14/85

SC/VPB:DQAVT
JWCraig
8/14/85

BC/VPB:DQAVT
GGZech
8/14/85