

SAFENIGHT TECHNOLOGY INC.*"the safer smoke detector network"*

2121 Electric Road SW
Roanoke, Virginia 24018
(703) 989-5738

October 2, 1995

Ms. Michelle Burgess, Mechanical Engineer
United States Nuclear Regulatory Commission
#2 Wide Flint North
11555 Rockville Pike T-8f5
Rockville, MD 20852

Re: Response to third comment to Sept. 26th letter

Dear Michelle:

Concerning the mounting screw pushing loose the
button:


- The screw length will be limited such that it will
not reach the button/source base.

Quality control/design conformity:

- 1) A screw will be specified that is sufficiently
short a length to accommodate all tolerances....
screw manufacturing, board thickness, source
holder... such that it does not come in contact
with the source/button.
- 2) Screw shipments will be sampled according to LTPD
5% tables prior to production by the manufacturer.

Should there be any other questions about our responses,
please let me know. Thank you.

Sincerely,



Scott N. Markwell
President

SNM/ct

SAFENIGHT TECHNOLOGY INC.*"the safer smoke detector network"*

2121 Electric Road SW
Roanoke, Virginia 24018
(703) 989-5738

F A X T R A N S M I T T A L S H E E T

To: Ms. Michelle Burgess, Mechanical EngineerCompany: USNRCRegarding: QuestionNumber of pages (including this sheet) 2From: Scott N. Markwell