



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

August 9, 1985

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: LaSalle County Station Unit 1  
Proposed Amendment to Technical  
Specification for Facility  
Operating License NPF-11  
Waiver of 18-Month Surveillance  
Interval - Revised Submittal  
NRC Docket No. 50-373

Reference (a): July 15, 1985 letter from H. L. Massin  
to H. R. Denton

Dear Mr. Denton:

Pursuant to 10 CFR 50.59, Commonwealth Edison proposed to amend Appendix A, Technical Specification to Facility Operating License NPF-11. These changes were submitted for your staff's review and approval in Reference (a). This revised submittal modifies reference (a) by deleting, from our original request, surveillances that were recently completed during an unplanned Unit 1 outage. Due dates for three of the surveillances have also been revised, however, no surveillance has a due date before September 22, 1985. Our request for a waiver of a maximum of 36 days remains as described in Reference (a). This revised submittal simply reduces the scope of our original request.

The unplanned Unit 1 outage started July 12, 1985 and was completed July 26, 1985. The outage was scheduled for 9 days with surveillances to be done the week of July 15, 1985. After July 21, the Unit was on day-by-day scheduling.

Work during this unplanned Unit 1 outage was constrained by:

- (1) Unit 2 startup (July 22, 1985) after a 5 month outage
- (2) Work on Unit 1 leaking valves (including leak rate testing these valves) - the reason for the outage
- (3) RHR out-of-service - all ECCS not available.

Attachment A identifies our original submittal revised to reflect those surveillances completed during the unplanned Unit 1 outage.

8508160333 850809  
PDR ADOCK 05000373  
P PDR

1001  
3/40

H. R. Denton

- 2 -

August 9, 1985


Attachment B deletes tech spec pages, that were originally requested to be revised, by removing the surveillances accomplished during the unplanned Unit 1 outage.

Commonwealth Edison is notifying the State of Illinois of our revised request for this amendment by transmitting a copy of this letter and its attachments to the designated State Official. The evaluation of significant hazards consideration is included in Reference (a).

Please direct any questions you may have regarding this matter to this office.

Three (3) signed original and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,

  
H. L. Massin


Nuclear Licensing Administrator

lm

Attachments A: Background and Discussion - Revised Reference (a).  
B: Technical Specification Change to NPF-11 (revised pages only)

cc: Region III Inspector - LSCS  
A. Bournia - NRR  
M. Parker - State of Ill.

SUBSCRIBED AND SWORN to  
before me this 9<sup>th</sup> day  
of August, 1985

  
Notary Public

0466K