



GPU Nuclear, Inc.
U.S. Route #9 South
Post Office Box 388
Forked River, NJ 08731-0388
Tel 609-971-4000

October 7, 1996
E000-96-011
6730-96-2309

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:


Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Facility Operating License No. DPR-16
Core Spray Sparger - 16R Outage Inspections

The Oyster Creek Nuclear Generating Station Technical Specifications, Appendix A, para. 6.9.3 d, and the Facility Operating License, para. 2.C.(5), require that a special report presenting the results of the in-service inspection of the core spray spargers during each refueling outage be provided for review and that authorization be obtained from the Commission's staff before the plant is restarted from each refueling outage.

Topical Report No. TR-110, which is enclosed for your review, is the core spray sparger inspection report for the Cycle 1C refueling outage. It describes the non-destructive examinations that were performed on the core spray spargers and the associated in-vessel annulus piping. The sparger assemblies and in-vessel annulus piping were inspected utilizing a remote visual camera examination supplemented with an optional air test. The report documents that no new relevant indications or anomalies were found and no change in pre-existing conditions were noted since the prior Cycle 15 refueling outage inspection.

If you have any questions or comments on this submittal, please contact Mr. Michael Laggart, Manager, Corporate Nuclear Licensing at (201) 316-7968.

Very truly yours,


for R. W. Keaten
Vice President and Director Engineering

9610090344 961007
PDR ADOCK 05000219
Q PDR

RWK/DPK/jr

Enclosure

cc: Administrator, Region 1
Senior Resident Inspector
Oyster Creek NRC Project Manager

090024

4047 1/1