

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

<u>PENETRATION NO.</u>	<u>ISOLATION CHANNEL</u>	<u>ISOLATION VALVE IDENTIFICATION NO.</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SECONDS)</u>
20B	NA NA	N ₂ -389 N ₂ -345	Nitrogen Supply	NA NA
20C	NA NA	N ₂ -346 N ₂ -392	Nitrogen Supply	NA NA
23	SIAS A	RCW-4260-CV	R.C. Drain Tank Drains	<7
24	SIAS B	PS-6531-SV	Oxygen Sample Line	<7
37	NA NA	PSW-1019 PSW-1008	Plant Water	NA NA
38	NA	DW-5460-CV*	Demineralized Water	NA
39	NA NA	SI-463 SI-455	Safety Injection Tank Test Line	NA NA
41	NA NA	SI-652-MOV (2) SI-651-MOV (2)	Shutdown Cooling	NA NA

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

<u>PENETRATION NO.</u>	<u>ISOLATION CHANNELS</u>	<u>ISOLATION VALVE IDENTIFICATION NO.</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SECONDS)</u>
14	SIAS A, CRS A SIAS B, CRS B	CPA-1412-CV (3) CPA-1413-CV (3)	Purge Air Outlet	<7** <u><7**</u>
15	SIAS A SIAS B	RE-5291-CV RE-5292-CV	Purge Air Monitor	<7 <u><7</u>
16	CIS A	CC-3832-CV	Component Cooling Water Inlet	<u><18</u>
18	CIS B	CC-3833-CV	Component Cooling Water Outlet	<u><18</u>
19A	NA CIS A	IA-337 IA-2080-MOV	Instrument Air	NA <u><13</u>
19B	NA NA	PA-1040* PA-1044*	Plant Air	NA NA
20A	NA NA NA NA NA	N ₂ -344 N ₂ -612-CV* N ₂ -622-CV* N ₂ -632-CV* N ₂ -642-CV*	Nitrogen Supply	NA NA NA NA NA

TABLE 3.7-4

SAFETY RELATED HYDRAULIC SNUBBERS*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR INACCESSIBLE (A or I)</u>	<u>HIGH RADIATION ZONE** (Yes or No)</u>	<u>ESPECIALLY DIFFICULT TO REMOVE (Yes or No)</u>
1-11-11	SERVICE WATER FROM CONTAINMENT COOLERS 5'	A	No	Yes
1-11-11A	SERVICE WATER PUMP SUCTION HDR 5'	A	No	No
1-11-13	SERVICE WATER FROM SPENT FUEL POOL COOLERS 5'	A	No	Yes
1-11-14	SERVICE WATER FROM CONTAINMENT COOLERS 5'	A	No	No
1-11-16	SERVICE WATER PUMP DISCHARGE HEADER 5'	A	No	No
1-11-18	SERVICE WATER PUMP DISCHARGE HEADER 5'	A	No	No
1-11-18A	SERVICE WATER PUMP DISCHARGE HEADER 5'	A	No	No

TABLE 3.7-4

SAFETY RELATED HYDRAULIC SNUBBERS*

<u>SNUBBER NO.</u>	<u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR INACCESSIBLE (A or I)</u>	<u>HIGH RADIATION ZONE** (Yes or No)</u>	<u>ESPECIALLY DIFFICULT TO REMOVE (Yes or No)</u>
1-11-1	SERVICE WATER PUMP #13 SUCTION 5'	A	No	No
1-11-2	SERVICE WATER PUMP #13 SUCTION 5'	A	No	No
1-11-4	SERVICE WATER PUMP #12 SUCTION 5'	A	No	No
1-11-5	SERVICE WATER PUMP #12 SUCTION 5'	A	No	No
1-11-7	SERVICE WATER PUMP #11 SUCTION 5'	A	No	No
1-11-8	SERVICE WATER PUMP #11 SUCTION 5'	A	No	No
1-11-9	SERVICE WATER PUMP #11 SUCTION 5'	A	No	No
1-11-10	SERVICE WATER HEADER FROM TURBINE BLDG. 5'	A	No	No

CALVERT CLIFFS-UNIT 1

3/4 7-27

Amendment No. 103