



UNION ELECTRIC COMPANY

1901 Gratiot Street, St. Louis

August 9, 1985

Donald F. Schnell
Vice President

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

ULNRC-1152

Dear Mr. Denton:


DOCKET NUMBER 50-483
CALLAWAY PLANT, UNIT 1
CALLAWAY PUMP AND VALVE INSERVICE TESTING PROGRAM

- Reference: 1) ULNRC-738 dated January 31, 1984
2) ULNRC-833 dated May 29, 1984
3) ULNRC-1039 dated February 11, 1985
4) ULNRC-1127 dated June 28, 1985

Reference 1 transmitted the Callaway Pump and Valve Inservice Testing Program. References 2, 3, and 4 transmitted updates to this same program. Included as attachments to this letter are further updates to the Callaway testing program. Attachment 1 is a brief description of the changes, and Attachment 2 contains revised replacement pages.

If there are any questions, please contact us.

Very truly yours,


for Donald F. Schnell

WEK/WAW/bjk
Attachments

8508190027 850809
PDR ADOCK 05000483
P PDR

STATE OF MISSOURI)
) S S
CITY OF ST. LOUIS)

Robert J. Schukai, of lawful age, being first duly sworn upon oath says that he is General Manager-Engineering (Nuclear) for Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Robert J. Schukai
Robert J. Schukai
General Manager-Engineering
Nuclear

SUBSCRIBED and sworn to before me this 9th day of August, 1985.

Barbara J. Pfaff
BARBARA J. PFAFF
NOTARY PUBLIC, STATE OF MISSOURI
MY COMMISSION EXPIRES APRIL 22, 1989
ST. LOUIS COUNTY

cc: Gerald Charnoff, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M. Street, N.W.
Washington, D.C. 20036

Nicholas A. Petrick
Executive Director
SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

G. C. Wright
Division of Projects and
Resident Programs, Chief, Section 1A
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Bruce Little
Callaway Resident Office
U.S. Nuclear Regulatory Commission
RR#1
Steedman, Missouri 65077

Tom Alexion
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop P-316
7920 Norfolk Avenue
Bethesda, MD 20014

bcc: 3456-0021.6 w/a
Nuclear Date
DFS/Chrono
J. F. McLaughlin
J. E. Birk
W. H. Weber
F. D. Field
R. J. Schukai
M. A. Stiller
S. E. Miltenberger w/a
H. Wuertenbaecher
D. W. Capone
A. C. Passwater
T. H. McFarland
R. P. Wendling
D. E. Shafer
D. J. Walker
G. P. Rathbun (KG&E)
J. H. Smith (Bechtel)
G56.37 (CA-460)
Compliance (J. E. Davis)
NSRB (Laura Robertson)
W. A. Witt (CA-460) w/a

ATTACHMENT TO ULNRC-1152
ASME SECTION XI
PUMP AND VALVE PROGRAM

CHANGES TO CALLAWAY NUCLEAR PLANT
INSERVICE TESTING PROGRAM

- ITEM 1: CHANGE: Add Relief Request #EJ-7
BASIS FOR CHANGE: As described in Relief Request #EJ-7
- ITEM 2: CHANGE: Add stroke test of EJ-HV-8716A, B
in the open direction.
BASIS FOR CHANGE: For Emergency Core Cooling System
Recirculation the valves must open
to switch from Cold Leg Recircul-
ation phase to Hot Leg Recircul-
ation phase.
- ITEM 3: CHANGE: Revise Maximum Allowable Stroke Time for
EG-HV-15.
BASIS FOR CHANGE: Due to new design document for
the valve.
- ITEM 4: CHANGE: Add Relief Request #EM-6
BASIS FOR CHANGE: As described in Relief Request
#EM-6.