



PECO NUCLEAR

A Unit of PECO Energy

Robert W. Boyce
Plant Manager
Limerick Generating Station

PECO Energy Company
Limerick Generating Station
PO Box 2300
Sanatoga, PA 19464-0920
610 718 2000

10CFR50.73

January 30, 1997

Locket No. 50-352
License No. NPF-39

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Licensee Event Report
Limerick Generating Station - Unit 1

This LER reports a condition prohibited by the Technical Specifications in that the D14 Emergency Diesel Generator Fuel Oil Storage Tank did not contain the minimum amount of fuel oil. The cause of this event was that a challenging method for determining the tank oil level resulted in an operator obtaining an incorrect tank level reading.

Reference:	Docket No. 50-352
Report Number:	1-96-022
Revision Number:	00
Event Date:	November 2, 1996
Discovery Date:	December 31, 1996
Report Date:	January 30, 1997
Facility:	Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464-2300

This LER is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B).

Very truly yours,

DBN:dbn

cc: H. J. Miller, Administrator Region I, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS

050007

9702050018 970130
PDR ADDCK 05000352
S PDR

11 FEB 1997