

DCS No: 5024550813
Date: August 14, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-85-58

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:

Northeast Nuclear Energy Co.
Millstone Point Unit 1
(DN 50-245)

Licensee Emergency Classification:
____ Notification of Unusual Event
____ Alert
____ Site Area Emergency
____ General Emergency
X Not Applicable

Subject: Reactor Trip - Media Interest

Millstone Unit 1 tripped at 12:07 p.m. on August 13, 1985, ending 374 days of continuous operation. The reactor trip and main steam line isolation occurred as a result of indicated steam line area high radiation. This condition resulted from air introduction into the feedwater system while placing a demineralizer in service. ECCS did not actuate and no abnormal releases occurred. Post-trip RCS samples do not indicate fuel damage. The resident inspector is onsite following licensee's actions. Media interest has occurred, because the licensee issued a press release.

The State of Connecticut has been informed.

CONTACT: D. Lipinski
203-447-3179

R. Summers
215-337-5104 (FTS 488-1104)

DISTRIBUTION:

H. St.	MNBB	Phillips	E/W	Willste	Mail:	ADM:DMB
Chairman Palladino	EDO	NRR	IE	NMSS		DOT:Trans only
Comm. Zech	PA		OIA	RES		
Comm. Bernthal	ELD		AEOD			
Comm. Roberts						
Comm. Asselstine						
ACRS	Air Rights		INPO----			
SECY	SP		NSAC----			
CA						
PDR	Regional Offices			TMI Resident Section		
				RI Resident Office		

Licensee:
(Reactor Licensees)

Region I Form 83
(Rev. July, 1984)

8508200150 850814
PDR I&E
PNO-I-85-058 PDR

IE - 34 *ok*