

Appendix

NOTICE OF VIOLATION

Commonwealth Edison Company

Docket No. 50-373

Docket No. 50-374

As a result of the inspection conducted on June 20 through July 24, 1985, and in accordance with the General Policy and Procedure for NRC Enforcement Action (10 CFR Part 2, Appendix C), the following violations were identified:

1. 10 CFR 50, Appendix B, Criterion XIV, as implemented by CECO's Quality Assurance Program, Quality Procedure No. 14-51, requires, in part, that measures be established to indicate the operating status of systems or components to prevent inadvertent operation.

Contrary to the above, the inspector noted two examples of inadequate procedures causing inadvertent equipment or system operations:

- a. Due to a procedure (equipment outage) not specifying the installation of a jumper to remove the RHR system high suction flow isolation switches from service, the shutdown cooling portion of the Unit 2 Residual Heat Removal System isolated on July 1, 1985.
- b. Due to a test procedure (LTS 300-10) failure to take all the appropriate equipment out of service, the Unit 2 Reactor Building Closed Cooling Water and Primary Containment Ventilation Systems isolated on June 26, 1985

This is a Severity Level IV violation (Supplement I).

2. Technical Specification 6.2.A.3 requires written procedures to be "prepared, approved, and adhered to ... for actions to be taken to correct specific and foreseen potential malfunctions of systems or components...."

Contrary to the above, the licensee failed to prepare and issue a procedure for shutting down one Control Rod Drive pump and starting another while operating the unit at full power which possibly could have prevented a reactor scram on June 29, 1985.

This is a Severity Level IV violation (Supplement I).


8508200461 850813
PDR ADDCK 05000373
Q PDR

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each violation: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

AUG 13 1985

8-13 85

Dated



N. Chrissotimos, Chief
Reactor Projects Branch 2