

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

William R. McCollum, Jr.
Vice President
(803) 831-3200 Office
(803) 831-3426 Fax



DUKE POWER

October 23, 1996

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station, Units 2
Docket Nos. 50-414
Second Ten Year Interval Inservice Inspection
Program
Request For Relief, 94-05, (TAC No. M95255)

Re: NRC Letter, Dated September 25, 1996, Request For
Written Commitment.

Gentlemen:

Per your request in the referenced letter, Catawba Nuclear
Station commits to the following:

Catawba Nuclear Station, when deferring nozzle
inspections to the end of the inspection interval,
will ensure there are no more than 10 years
between inspections, except where the length of
the 10-year interval is adjusted in accordance
with IWA-2430.

Should there be any questions concerning this subject or
should additional information be required, please call
D. Tower at (803) 831-3419.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'William R. McCollum, Jr.'.

William R. McCollum, Jr.

A04710

Document Control Desk
Page 2
October 23, 1996

XC:

S.D. Ebnetter, Regional Administrator
Region II

R.J. Freudenberger, Senior Resident Inspector
Catawba Nuclear Station

P.S. Tam, Senior Project Manager
ONRR