

NOTATION VOTE

RESPONSE SHEET

TO: John C. Hoyle  
Secretary of the Commission

FROM: COMMISSIONER DICUS

SUBJECT: SECY-96-248, PROPOSED RULE ON CHANGES TO NUCLEAR  
POWER PLANT SECURITY REQUIREMENTS, 10 CFR  
PART 73


Approved X in part Disapproved X in part Abstain     

Not Participating      Request Discussion     


COMMENTS:

Except as noted below, I approve the staff request to publish the proposed rule with the replacement of the deleted rule statement as noted in the attachment to this vote.

I disapprove the staff proposal to change the requirement for access list reapproval from at least once every 31 days to annually. This time period seems too long particularly since operating experience with a change in this requirement has yet to be obtained. I request the staff to consider either a quarterly reapproval of the access list or an annual reapproval during normal operations with a monthly reapproval during outage or shutdown conditions for those facilities that have not permanently ceased operations.

  
SIGNATURE

Release Vote / X /

  
DATE

Withhold Vote /      /

Entered on "AS" Yes      No

(5) A numbered picture badge identification system must be used for all individuals who are authorized access to protected areas without escort. An individual not employed by the licensee but who requires frequent and extended access to protected and vital areas may be authorized access to such areas without escort provided that he or she displays a licensee-issued picture badge upon entrance into the protected area which indicates:

- (i) Non-employee-no escort required;
- (ii) areas to which access is authorized; and
- (iii) the period for which access has been authorized.

Badges shall be displayed by all individuals while inside the protected area.

\* \* \* \* \*

(7) \*\*\*

(i) \*\*\*

(A) Establish a current authorization access list for all vital areas.

The access list must be updated by the cognizant licensee manager or supervisor at least once every 31 days and must be reapproved at least annually. *(Missing Statement/requirement)*

\* \* \* \* \*

(d)(8) All keys, locks, combinations, and related access control devices used to control access to protected areas and vital areas must be controlled to reduce the probability of compromise. Whenever there is evidence or suspicion that any key, lock, combination, or related access control devices may have been compromised, it must be changed or rotated. The licensee shall issue keys, locks, combinations and other access control

*The licensee shall include on the access list only individuals whose specific duties require access to vital areas during nonemergency conditions.*