

UNITED STATES NUCLEAR REGULATORY COMMISSIONCOMMONWEALTH EDISON COMPANYDOCKET NOS. 50-373 AND 50-374NOTICE OF WITHDRAWAL OF APPLICATION FOR  
AMENDMENTS TO FACILITY OPERATING LICENSES

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Commonwealth Edison Company (ComEd, the licensee) to withdraw its June 21, 1996, application for proposed amendment to Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, located in LaSalle County, Illinois.


The proposed amendment would have revised the technical specifications (TS) by extending the surveillance interval for testing of the Control Room and Auxiliary Electric Equipment Room Emergency Filtration System from 18 months to 24 months and would have allowed a one-time extension of the allowed outage time for this system from 7 days to 30 days.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on August 14, 1996 (61 FR 42278). However, by letter dated October 8, 1996, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated June 21, 1996, and the licensee's letter dated October 8, 1996, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Jacobs Memorial Library, Illinois Valley Community College, Oglesby, Illinois 61348.

Dated at Rockville, Maryland, this 1st day of November 1996.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Donna M. Skay".

Donna M. Skay, Project Manager  
Project Directorate III-2  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation