

NIAGARA MOHAWK

GENERATION
BUSINESS GROUP

NINE MILE POINT NUCLEAR STATION/LAKE ROAD, P.O. BOX 63, LYCOMING, NEW YORK 13093

January 31, 1997
NMP2L 1685

U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738
Attn: Dr. Gerald H. Weidenhamer, Mail Stop 10E10

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Subject: Request for Pressure Locking Test Information

Dear Dr. Weidenhamer:

As explained by members of my staff, Niagara Mohawk Power Corporation (NMPC) would like for the following pressure locking testing results be provided to our consultant, Kalsi Engineering, Inc., to support our evaluations and preparations for a predecisional enforcement conference with NRC Region I.

Pressure locking tests with motor-torque measurements


Test Stroke	Test Type	Test Parameters			
		P _{up} (psig)	P _{booster} (psig)	P _{down} (psig)	T _{booster} (F)
Walworth:					
V3002	S	0	0		70
V3011	PL	1001	0		70
V3012	PL	1200	0		70
V3013	HD	1250	1250	0	70
V3014	S	0	0	0	70
V3017	PL	1200	0	0	70
V3BHT9	PL	1015	0	0	205
A/D:					
ADP01	S	0	0	0	70
ADP02	HD	1200	1200	0	70
ADP03	HD	1200	0	1200	70

110045
9702160029

X A 2/13/97 2PP

We believe that the requested data will assist us in determining the validity of our assumptions used in GL 89-10 calculations. It is noted that in order to utilize the data in a time frame consistent with our requirements, we would like to receive this information by February 7, 1997. If you have any questions concerning this request, contact Mr. G. J. Gresock at (315) 349-7010.

Very truly yours,

A handwritten signature in black ink, appearing to read "M. J. McCormick Jr.", with a stylized flourish at the end.

M. J. McCormick Jr
Vice President Nuclear Engineering

MJM/GJG/kap

xc: Document Control Desk
Regional Administrator, Region I
Mr. S. S. Bajwa, Acting Director, Project Directorate I-1, NRR
Mr. B. S. Norris, Senior Resident Inspector
Mr. D. S. Hood, Senior Project Manager, NRR
Records Management