

Maine Yankee

RELIABLE ELECTRICITY SINCE 1972

329 BATH ROAD • BRUNSWICK, MAINE 04011 • (207) 798-4100

November 1, 1996

MN-96-158

JRH-96-239

UNITED STATES NUCLEAR REGULATORY COMMISSION

Attention: Document Control Desk

Washington, DC 20555

References: (a) License No. DPR-36 (Docket No. 50-309)
(b) Letter From Maine Yankee to NRC, dated October 3, 1996 (MN-96-150)

Subject: Containment High Range Radiation Monitor


Gentlemen:

Reference (b) is a notification that the A Train Containment High Range Radiation Area Monitor, RM-6113A, was declared inoperable on September 26, 1996, due to spiking. The monitor was removed from service; the control module was inspected and cleaned; and the unit was placed back in service for trending purposes only.

On October 25, 1996, an operability determination was performed and the unit was declared operable. There has been no further spiking, monitor indication and response has been normal, and daily checks of the monitor have been satisfactory.

A spare monitor has been ordered.

Very truly yours,



James R. Hebert, Manager
Licensing & Engineering Support Department

JRH/mwf

Enclosure

c: Mr. Hubert Miller
Mr. J. T. Yerokun
Mr. Daniel H. Dorian
Mr. Patrick J. Dostie
Mr. Uldis Vanaags

9611080063 961101
PDR ADOCK 05000309
P PDR

ADD 1/0