



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 2 1985

Docket No. 50-461

Mr. Frank A. Spangenberg
Director of Nuclear Licensing &
Configuration Management
Clinton Power Station
P.O. Box 306
Mail Code V920
Clinton, Illinois 61727

Dear Mr. Spangenberg:

SUBJECT: SEISMIC QUALIFICATION OF EQUIPMENT (SQRT) AND PUMP AND VALVE
OPERABILITY QUALIFICATION (PVORT) AUDITS - OUTSTANDING ISSUES
7ii AND 7iii

We have reviewed the master lists related to the installation and qualification status of the equipment identified in the enclosure to your letter dated July 30, 1985. The information provided indicates that only 71% of the equipment is currently installed and qualified and that approximately 80% will be at the time of the audit. Although this is below the 85% to 90% normally recommended by the staff, based on your request we have decided to proceed with the audit scheduled for the week of August 26, 1985. However, since the percentage of the equipment qualified and installed at the time of the audit will be below that recommended by the staff a followup audit may be required. Our review and evaluation of the August audit will determine if a followup audit is necessary.

As per your July 30, 1985 letter and subsequent telephone conversations the following schedule associated with these audits have been mutually agreed to.

Action Item	SQRT DATES	PVORT DATES
NRC Selection of items for audit	8/7/85	8/2/85
IP provide long forms for items selected	8/19/85	8/14/85
NRC to identify two surprise items	N/A	8/23/85
NRC select eight items for audit	N/A	8/21 to 8/23/85

8508210311 850802
PDR ADOCK 05000461
A PDR

If you have any questions regarding this issue or the schedule please contact the licensing project manager for your application.

Sincerely,

Walter R. Butler

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page

AUG 2 1985

If you have any questions regarding this issue or the schedule please contact the licensing project manager for your application.

Sincerely,

~~Original signed by:~~

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page

DISTRIBUTION

Docket File

NRC PDR
Local PDR
PRC System
NSIC
LB#2 Reading
EHylton
BSiegel
Goddard, OELD
ACRS (16)
JPartlow
BGrimes
EJordan
JLombardo
ALee

LB#2/DL/PH
BSiegel:lb
08/1/85

EQB
GBagchi
08/2/85

LB#2/DL/BC
WButler
08/2/85

WB

Mr. Frank A. Spangenberg
Illinois Power Company

Clinton Power Station
Unit 1

cc:

Mr. Allen Samuelson, Esquire
Assistant Attorney General
Environmental Control Division
Southern Region
500 South Second Street
Springfield, Illinois 62706

Jean Foy, Esquire
511 W. Nevada
Urbana, Illinois 61801

Mr. D. P. Hall
Vice President
Clinton Power Station
P. O. Box 678
Clinton, Illinois, 61727

Richard B. Hubbard
Vice President
Technical Associates
1723 Hamilton Ave. - Suite K
San Jose, CA 95125

Mr. H. R. Victor
Manager-Nuclear Station Engineering Dpt.
Clinton Power Station
P. O. Box 678
Clinton, Illinois 61727

Sheldon Zabel, Esquire
Schiff, Hardin & Waite
7200 Sears Tower
233 Wacker Drive
Chicago, Illinois 60606

Resident Inspector
U. S. Nuclear Regulatory Commission
RF 3, Box 229 A
Clinton, Illinois 61727

Mr. R. C. Heider
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, Illinois 60603

Mr. L. Larson
Project Manager
General Electric Company
175 Curtner Avenue, N/C 395
San Jose, California 95125

Regional Administrator, Region III
759 Roosevelt Road
Olen Ellyn, Illinois 60137