



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

*PRR*

DEC 14 1984

NOTE TO: Vincent S. Noonan

SUBJECT: Telephone Discussion with Mr. M. Jones (TUEC)  
initiated by Mr. Jones 12/5/84  
Comanche Peak Unit 1 & 2 Docket No. 50-445

Mr. Jones asked whether we could identify areas where unacceptable cable splices may have been identified in addition to those in instrument panels. I indicated to him that such information will be made available shortly, when the TRT SERs are issued.

Additionally, he informed me of the approach being taken to address potential violations of cable separation, where an analysis is being conducted assessing circuit service, electrical duty and environment. I agreed that the approach appears adequate.

A handwritten signature in cursive script, appearing to read "E. Marinos".

E. Marinos, TRT

cc: J. Calvo  
R. C. Tang  
Docket File 50-445

8508220034 841214  
PDR ADOCK 05000445  
A PDR