

Mr. Robert Quillin, Director
Radioactive Control Division
Colorado Department of Public Health
and Environment
4300 Cherry Creek Drive South (RCD-DO-B1)
Denver, CO 80222-1530

NOV 1 1996

Dear Mr. Quillin:


We have reviewed the draft proposed Colorado rule, Part 19, Licensing and Radiation Safety Requirements for Irradiators dated October 10, 1996. The proposed rule was reviewed by comparison to the equivalent NRC regulations in 10 CFR Part 36. Dr. Stephen N. Salomon acknowledged receipt on October 10, 1996, of an earlier version of the proposed rule dated September 18, 1996, that was sent by your staff, Ms. Michelle Sime Moore, to Charles Hackney, Regional IV State Liaison Officer, on September 17, 1996. Dr. Salomon received by facsimile on October 21, 1996 your staff's follow up version dated October 10. The revised version included the omissions, mainly of a word processing nature, that Dr. Salomon flagged to the attention of Mr. Chuck Mattson in a telephone call on October 10, 1996. Also, Mr. Mattson flagged to Dr. Salomon several additional word changes that were incorporated by him since the initial draft of September 18, 1996, was sent.

As the result of the review of the October 10, 1996, version, we have no comments. Under our current procedure, a finding that a rule meets the compatibility requirements may only be made based on a review of the final text of the rule. However, we have determined that if the proposed rules were adopted without significant change, they would be compatible.

We request that when the proposed rules are adopted and published as final rules, a copy of the "as published" rules be provided to us for review. As requested in our All Agreement States Letter SP-96-027, "Request to Highlight Changes to Agreement State Regulations Submitted to NRC for Compatibility Review" (March 1, 1996), please highlight the final changes and send one copy in a computer readable format, if possible.

If you have any questions regarding the comments or any of the NRC rules used in the review, please contact me or Dr. Stephen N. Salomon of my staff at (301) 415-2368, or INTERNET: SNS@NRC.GOV.

9611080212 961101
PDR STPRG ESGCO
PDR

Sincerely, 
PAUL H. LOHAUS

Paul H. Lohaus, Deputy Director
Office of State Programs

Distribution:

DIR RF (6S246)
RLBangart
SNSalomon
SDroggitis
Colorado File

DCD (SP08)
PLohaus
FCameron

PDR (YES)
RBlanton

080050

DOCUMENT NAME: G:\SNS\6S246.SNS

*See previous concurrence.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	OSP SNS	C	OSP:DD	OGC	OSP:D
NAME	SNSalomon:maj		PLohaus	FXCameron	RLBangart
DATE	10/23/96		10/1/96	10/2/96	10/6/96

OSP FILE: SP-AG-5

NRC FILE CENTER COPY

9611080212



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 1, 1996

Mr. Robert Quillin, Director
Radioactive Control Division
Colorado Department of Public Health
and Environment
4300 Cherry Creek Drive South (RCD-DO-B1)
Denver, CO 80222-1530

Dear Mr. Quillin:

We have reviewed the draft proposed Colorado rule, Part 19, Licensing and Radiation Safety Requirements for Irradiators dated October 10, 1996. The proposed rule was reviewed by comparison to the equivalent NRC regulations in 10 CFR Part 36. Dr. Stephen N. Salomon acknowledged receipt on October 10, 1996, of an earlier version of the proposed rule dated September 18, 1996, that was sent by your staff, Ms. Michelle Sime Moore, to Charles Hackney, Regional IV State Liaison Officer, on September 17, 1996. Dr. Salomon received by facsimile on October 21, 1996 your staff's follow up version dated October 10. The revised version included the omissions, mainly of a word processing nature, that Dr. Salomon flagged to the attention of Mr. Chuck Mattson in a telephone call on October 10, 1996. Also, Mr. Mattson flagged to Dr. Salomon several additional word changes that were incorporated by him since the initial draft of September 18, 1996, was sent.

As the result of the review of the October 10, 1996, version, we have no comments. Under our current procedure, a finding that a rule meets the compatibility requirements may only be made based on a review of the final text of the rule. However, we have determined that if the proposed rules were adopted without significant change, they would be compatible.

We request that when the proposed rules are adopted and published as final rules, a copy of the "as published" rules be provided to us for review. As requested in our All Agreement States Letter SP-96-027, "Request to Highlight Changes to Agreement State Regulations Submitted to NRC for Compatibility Review" (March 1, 1996), please highlight the final changes and send one copy in a computer readable format, if possible.

If you have any questions regarding the comments or any of the NRC rules used in the review, please contact me or Dr. Stephen N. Salomon of my staff at (301) 415-2368, or INTERNET: SNS@NRC.GOV.

Sincerely,

Paul H. Lohaus, Deputy Director
Office of State Programs

☐ 1 - PAGE NOTE☒ DOCUMENT COVER SHEET

Radiation
Control
Division

Colorado Department
of Public Health
and Environment

Radiation Control Division
Colorado Department of Public Health and Environment
4300 Cherry Creek Drive South
Denver, Colorado 80222-1530
Voice telephone number (303) 692-3030
FAX telephone number (303) 782-5083

TO THE ATTENTION OF <i>Steve Salamon</i>	From <i>Michelle Ann Moore</i>
	Date <i>10/22/96</i>
Voice telephone number	Total pages, including cover sheet <i>41</i>
FAX telephone number	

- | | | | | |
|--|--|---|---|---|
| <input type="checkbox"/> Urgent | <input type="checkbox"/> Please reply | <input type="checkbox"/> For your comment | <input type="checkbox"/> Hardcopy will follow | <input type="checkbox"/> For your information |
| <input type="checkbox"/> Action needed | <input type="checkbox"/> Please reply ASAP | <input type="checkbox"/> For your review | <input type="checkbox"/> Please acknowledge | <input type="checkbox"/> Per your request |

COMMENTS

Proposed Part 19

*Two transmissions
of 20 pgs.*

Please call (303) 692-3030 if you have any problems receiving this transmission

DRAFT

October 10, 1996

PART 19

LICENSES AND RADIATION SAFETY REQUIREMENTS FOR IRRADIATORS

GENERAL PROVISIONS

RH 19.1 *Not required* Purpose and Scope.

✓ 19.1.1 Part 19 contains requirements for the issuance of a license authorizing the use of sealed sources containing radioactive materials in irradiators used to irradiate objects or materials using gamma radiation. Part 19 also contains requirements for operating irradiators. The requirements of this part are in addition to the requirements of Parts 3, 4, 10, 12, 13, and 17. Nothing in this part relieves the licensee from complying with other applicable Federal, State and local regulations governing the siting, zoning, land use, and building code requirements for industrial facilities.

✓ 19.1.2 The regulations in this part apply to panoramic irradiators that have either dry or wet storage of the radioactive sealed sources and to underwater irradiators in which both the source and the product being irradiated are under water. Irradiators whose dose rates exceed 5 grays (500 rads) per hour at 1 meter from the radioactive sealed sources in air or in water, as applicable for the irradiator type, are covered by this part.

✓ 19.1.3 The regulations in this part do not apply to self-contained dry-source-storage irradiators (those in which both the source and the area subject to irradiation are contained within a device and are not accessible by personnel), medical radiology or teletherapy, radiography (the irradiation of materials for nondestructive

DRAFT

October 10, 1996

testing purposes), gauging, or open-field (agricultural)
irradiations.

RH 19.2 *Div 2* Definitions.

✓ "Annually" means either (1) at intervals not to exceed 1 year or
(2) once per year, at about the same time each year (plus or minus
1 month).

✓ "Doubly encapsulated sealed source" means a sealed source in which
the radioactive material is sealed within a capsule and that
capsule is sealed within another capsule.

✓ "Irradiator" means a facility that uses radioactive sealed sources
for the irradiation of objects or materials and in which radiation
dose rates exceeding 5 grays (500 rads) per hour exist at 1 meter
from the sealed radioactive sources in air or water, as applicable
for the irradiator type, but does not include irradiators in which
both the sealed source and the area subject to irradiation are
contained within a device and are not accessible to personnel.

✓ "Irradiator operator" means an individual who has successfully
completed the training and testing described in RH 19.18 and is
authorized by the terms of the license to operate the irradiator
without a supervisor present.

✓ "Panoramic dry-source-storage irradiator" means an irradiator in
which the irradiations occur in air in areas potentially

D R A F T

October 10, 1996

accessible to personnel and in which the sources are stored in shields made of solid materials. The term includes beam-type dry-source-storage irradiators in which only a narrow beam of radiation is produced for performing irradiations.

✓ "Panoramic irradiator" means an irradiator in which the irradiations are done in air in areas potentially accessible to personnel. The term includes beam-type irradiators.

✓ "Panoramic wet-source-storage irradiator" means an irradiator in which the irradiations occur in air in areas potentially accessible to personnel and in which the sources are stored under water in a storage pool.

✓ "Pool irradiator" means any irradiator at which the sources are stored or used in a pool of water including panoramic wet-source-storage irradiators and underwater irradiators.

✓ "Product conveyor system" means a system for moving the product to be irradiated to, from, and within the area where irradiation takes place.

✓ "Radiation room" means a shielded room in which irradiations take place. Underwater irradiators do not have radiation rooms.

✓ "Seismic area" means any area where the probability of a horizontal acceleration in rock of more than 0.3 times the acceleration of gravity in 250 years is greater than 10 percent, as designated by the U.S. Geological Survey.

added
per telecon 10/10/96
with Chuck Mattson, CO

DRAFT

October 10, 1996

1 "Underwater irradiator" means an irradiator in which the sources
2 always remain shielded under water and humans do not have access
3 to the sealed sources or the space subject to irradiation without
4 entering the pool.

5
6
7 Specific Licensing Requirements

8
9 RH 19.3 *Not required* Application For a Specific License.

10
11 19.3.1 A person shall file an application for a specific license
12 authorizing the use of sealed sources in an irradiator pursuant to
13 RH 3.8 of the regulations.

14
15 RH 19.4 *Div 2* Specific Licenses for Irradiators.

16
17 ✓ 19.4.1 The Department will approve an application for a specific license
18 for the use of licensed material in an irradiator if the applicant
19 meets the requirements contained in this section.

20
21 ✓ 19.4.2 The applicant shall satisfy the general requirements specified in
22 RH 3.9 of the regulations and the requirements contained in this
23 part.

24
25 ✓ 19.4.3 The applicant must describe the training provided to irradiator
26 operators including:

27
28 ✓ 19.4.3.1 Classroom training;

D R A F T

October 10, 1996

- 1 ✓ 19.4.3.2 On-the-job or simulator training;
2
- 3 ✓ 19.4.3.3 Safety reviews;
4
- 5 ✓ 19.4.3.4 Means employed by the applicant to test each operator's
6 understanding of the Department's regulations and licensing
7 requirements and the irradiator operating and emergency
8 procedures; and
9
- 10 ✓ 19.4.3.5 Minimum training and experience of personnel who may provide
11 training.
12
- 13 ✓ 19.4.4 The application must include an outline of the written operating
14 and emergency procedures listed in RH 19.19 that describes the
15 radiation safety aspects of the procedures.
16
- 17 ✓ 19.4.5 The application must describe the organizational structure for
18 managing the irradiator, specifically the radiation safety
19 responsibilities and authorities of the radiation safety officer
20 and those management personnel who have important radiation safety
21 responsibilities or authorities. In particular, the application
22 must specify who, within the management structure, has authority
23 to stop unsafe operations. The application must also describe the
24 training and experience required for the position of radiation
25 safety officer.
26
- 27 ✓ 19.4.6 The application must include a description of the access control
28 systems required by RH 19.8, the radiation monitors required by RH
29 19.11, the method of detecting leaking sources required by RH

D R A F T

October 10, 1996

19.22 including the sensitivity of the method, and a diagram of the facility that shows the locations of all required interlocks and radiation monitors.

19.4.7 ✓ If the applicant intends to perform leak testing of dry-source-storage sealed sources, the applicant shall establish procedures for leak testing and submit a description of these procedures to the Department. The description must include the:

19.4.7.1 ✓ Instruments to be used;

19.4.7.2 ✓ Methods of performing the analysis; and

19.4.7.3 ✓ Pertinent experience of the individual who analyzes the samples.

19.4.8 ✓ If licensee personnel are to load or unload sources, the applicant shall describe the qualifications and training of the personnel and the procedures to be used. If the applicant intends to contract for source loading or unloading at its facility, the loading or unloading must be done by an organization specifically authorized by the U. S. Nuclear Regulatory Commission or an Agreement State to load or unload irradiator sources.

19.4.9 ✓ The applicant shall describe the inspection and maintenance checks, including the frequency of the checks required by RH 19.23.

RH 19.5 ✓ Start of Construction.

D R A F T

October 10, 1996

19.5.1 The applicant may not begin construction of a new irradiator prior to the submission to the Department of both the application for a license for the irradiator and the fee required by Part 12 of the regulations. As used in this section, the term "construction" includes the construction of any portion of the permanent irradiator structure on the site but does not include: engineering and design work, purchase of a site, site surveys or soil testing, site preparation, site excavation, construction of warehouse or auxiliary structures, and other similar tasks. Any activities undertaken prior to the issuance of a license are entirely at the risk of the applicant and have no bearing on the issuance of a license with respect to the requirements of The Act, and rules, regulations, and orders issued under The Act.

Not required
RH 19.6 Applications for Exemptions.

19.6.1 Any application for a license or for amendment of a license authorizing use of a teletherapy-type unit for irradiation of materials or objects may include proposed alternatives for the requirements of this part. The Department will approve the proposed alternatives if the applicant provides adequate rationale for the proposed alternatives and demonstrates that they are likely to provide an adequate level of safety for workers and the public.

§ 36.19 Request for written comments,
This is missing. Chuck Mattson says
Design and Performance Requirements for Irradiators

Div 2
covered
in Part 3
10/10/96

Div 2
RH 19.7 Performance Criteria for Sealed Sources.

D R A F T

October 10, 1996

1 19.7.1 Requirements. Sealed sources installed after January 1, 1997:

2
3 19.7.1.1 ✓ Must have a certificate of registration issued by the U.S.
4 Nuclear Regulatory Commission or an Agreement State;

5
6 19.7.1.2 ✓ Must be doubly encapsulated;

7
8 19.7.1.3 ✓ Must use radioactive material that is as nondispersible as
9 practical and that is as insoluble as practical if the
10 source is used in a wet-source-storage or wet-source-change
11 irradiator;

12
13 19.7.1.4 ✓ Must be encapsulated in a material resistant to general
14 corrosion and to localized corrosion, such as 316L stainless
15 steel or other material with equivalent resistance if the
16 sources are used in irradiator pools; and

17
18 19.7.1.5 ✓ In prototype testing of the sealed source, must have been
19 leak tested and found leak-free after each of the tests
20 described in RH 19.7.1.5.1 through 19.7.1.5.6.

21
22 19.7.1.5.1 ✓ Temperature. The test source must be held at -40°C for
23 20 minutes, 600°C for 1 hour, and then be subjected to
24 a thermal shock test with a temperature drop from
25 600°C to 20°C within 15 seconds.

26
27 19.7.1.5.2 ✓ Pressure. The test source must be twice subjected for
28 at least 5 minutes to an external pressure (absolute)
29 of 2 million newtons per square meter.

D R A F T

October 10, 1996

19.7.1.5.3

✓ Impact. A 2-kilogram steel weight, 2.5 centimeters in diameter, must be dropped from a height of 1 meter onto the test source.

19.7.1.5.4

✓ Vibration. The test source must be subjected 3 times for 10 minutes each to vibrations sweeping from 25 hertz to 500 hertz with a peak amplitude of 5 times the acceleration of gravity. In addition, each test source must be vibrated for 30 minutes at each resonant frequency found.

19.7.1.5.5

✓ Puncture. A 50-gram weight and pin, 0.3-centimeter pin diameter, must be dropped from a height of 1 meter onto the test source.

19.7.1.5.6

✓ Bend. If the length of the source is more than 15 times larger than the minimum cross-sectional dimension, the test source must be subjected to a force of 2000 newtons at its center equidistant from two support cylinders, the distance between which is 10 times the minimum cross-sectional dimension of the source.

RH 19.8 Access Control

19.8.1

✓ Each entrance to a radiation room at a panoramic irradiator must have a door or other physical barrier to prevent inadvertent entry of personnel if the sources are not in the shielded position. Product conveyor systems may serve as barriers as long as they

DRAFT

October 10, 1996

reliably and consistently function as a barrier. It must not be possible to move the sources out of their shielded position if the door or barrier is open. Opening the door or barrier while the sources are exposed must cause the sources to return promptly to their shielded position. The personnel entrance door or barrier must have a lock that is operated by the same key used to move the sources. The doors and barriers must not prevent any individual in the radiation room from leaving.

19.8.2 ✓ In addition, each entrance to a radiation room at a panoramic irradiator must have an independent backup access control to detect personnel entry while the sources are exposed. Detection of entry while the sources are exposed must cause the sources to return to their fully shielded position and must also activate a visible and audible alarm to make the individual entering the room aware of the hazard. The alarm must also alert at least one other individual who is onsite of the entry. That individual shall be trained on how to respond to the alarm and be prepared to promptly render or summon assistance.

19.8.3 ✓ A radiation monitor must be provided to detect the presence of high radiation levels in the radiation room of a panoramic irradiator before personnel entry. The monitor must be integrated with personnel access door locks to prevent room access when radiation levels are high. Attempted personnel entry while the monitor measures high radiation levels, must activate the alarm described in RH 19.8.2. The monitor may be located in the entrance (normally referred to as the maze) but not in the direct radiation beam.

chuck does not know 19 - 10
why important. CC has a
pool irradiator only. I am
trying to get him technical
guidance to explain. Steve

Got good answer
from Steve McGuire
10/24 and e-mailed
to Mattson 10/24/96

DRAFT

October 10, 1996

19.8.4 ✓ Before the sources move from their shielded position in a panoramic irradiator, the source control must automatically activate conspicuous visible and audible alarms to alert people in the radiation room that the sources will be moved from their shielded position. The alarms must give individuals enough time to leave the room before the sources leave the shielded position.

19.8.5 ✓ Each radiation room at a panoramic irradiator must have a clearly visible and readily accessible control that would allow an individual in the room to make the sources return to their fully shielded position.

19.8.6 ✓ Each radiation room of a panoramic irradiator must contain a control that prevents the sources from moving from the shielded position unless the control has been activated and the door or barrier to the radiation room has been closed within a preset time after activation of the control.

19.8.7 ✓ Each entrance to the radiation room of a panoramic irradiator and each entrance to the area within the personnel access barrier of an underwater irradiator must have a sign bearing the radiation symbol and the words, "Caution (or danger) radioactive material".

✓ Panoramic irradiators must also have a sign stating "Grave danger, very high radiation area", but the sign may be removed, covered, or otherwise made inoperative when the sources are fully shielded.

19.8.8 ✓ If the radiation room of a panoramic irradiator has roof plugs or other movable shielding, it must not be possible to operate the irradiator unless the shielding is in its proper location. This

See §20.1902 (c) and draft Reg Guide D0003, p.19.

changed per
telecon
10/10/96
Mattson/
Salomon

This is
per Part 20,
not Part 36,
that is
incorrect.
Blanton
says there
is a memo
that
addresses
this concern.
Steve

DRAFT

October 10, 1996

requirement may be met by interlocks that prevent operation if shielding is not placed properly or by an operating procedure requiring inspection of shielding before operating.

19.8.9 ✓ Underwater irradiators must have a personnel access barrier around the pool which must be locked to prevent access when the irradiator is not attended. Only operators and facility management may have access to keys to the personnel access barrier. There must be an intrusion alarm to detect unauthorized entry when the personnel access barrier is locked. Activation of the intrusion alarm must alert an individual (not necessarily onsite) who is prepared to respond or summon assistance.

RH 19.9 *Div 2* Shielding

19.9.1 ✓ The radiation dose rate in areas that are normally occupied during operation of a panoramic irradiator may not exceed 0.02 millisievert (2 millirem) per hour at any location 30 centimeters or more from the wall of the room when the sources are exposed. The dose rate must be averaged over an area not to exceed 100 square centimeters having no linear dimension greater than 20 centimeters. Areas where the radiation dose rate exceeds 2 millirem (0.02 millisieverts) per hour must be locked, roped off, or posted.

19.9.2 ✓ The radiation dose at 30 centimeters over the edge of the pool of a pool irradiator may not exceed 0.02 millisieverts (2 millirem) per hour when the sources are in the fully shielded position.

DRAFT

October 10, 1996

1 19.9.3 ✓ The radiation dose rate at 1 meter from the shield of a dry-
2 source-storage panoramic irradiator when the source is shielded
3 may not exceed 0.02 millisievert (2 millirem) per hour and at 5
4 centimeters from the shield may not exceed 0.2 millisievert (20
5 millirem) per hour.

6
7 RH 19.10 *Div 2* ✓ Fire Protection.
8

9 19.10.1 ✓ The radiation room at a panoramic irradiator must have heat and
10 smoke detectors. The detectors must activate an audible alarm. The
11 alarm must be capable of alerting a person who is prepared to
12 summon assistance promptly. The sources must automatically become
13 fully shielded if a fire is detected.

14
15 19.10.2 ✓ The radiation room at a panoramic irradiator must be equipped with
16 a fire extinguishing system capable of extinguishing a fire
17 without the entry of personnel into the room. The system for the
18 radiation room must have a shut-off valve to control flooding into
19 unrestricted areas.

20
21 RH 19.11 *Div 2* ✓ Radiation Monitors.
22

23 19.11.1 ✓ Irradiators with automatic product conveyor systems must have a
24 radiation monitor with an audible alarm located to detect loose
25 radioactive sources that are carried toward the product exit. If
26 the monitor detects a source, an alarm must sound and product
27 conveyors must stop automatically. The alarm must be capable of
28 alerting an individual in the facility who is prepared to summon
29 assistance. Underwater irradiators in which the product moves

D R A F T

October 10, 1996

1 within an enclosed stationary tube are exempt from the
2 requirements of this paragraph.

3
4 19.11.2 ✓ Underwater irradiators that are not in a shielded radiation room
5 must have a radiation monitor over the pool to detect abnormal
6 radiation levels. The monitor must have an audible alarm and a
7 visible indicator at entrances to the personnel access barrier
8 around the pool. The audible alarm may have a manual shut-off. The
9 alarm must be capable of alerting an individual who is prepared to
10 respond promptly.

11
12 RH 19.12 *Div 2* Control of Source Movement.

13
14 19.12.1 ✓ The mechanism that moves the sources of a panoramic irradiator
15 must require a key to actuate. Actuation of the mechanism must
16 cause an audible signal to indicate that the sources are leaving
17 the shielded position. Only one key may be used at any time, and
18 only one operator or facility management may possess it. The key
19 must be attached to a portable radiation survey meter by a chain
20 or cable. The lock for source control must be designed so that the
21 key may not be removed if the sources are in an unshielded
22 position. The door to the radiation room must require the same
23 key.

24
25 19.12.2 ✓ The console of a panoramic irradiator must have a source position
26 indicator that indicates when the sources are in the fully
27 shielded position, when they are in transit, and when the sources
28 are exposed.
29

DRAFT

October 10, 1996

19.12.3 ✓ The control console of a panoramic irradiator must have a control
at promptly returns the sources to the shielded position.

19.12.4 ✓ Each control for a panoramic irradiator must be clearly marked as
to its function.

7 RH 19.13 *Div 2* Irradiator Pools.

19.13.1 ✓ For licenses initially issued after January 1, 1997, irradiator
pools must either:

19.13.1.1 ✓ Have a water-tight stainless steel liner or a liner
metallurgically compatible with other components in the
pool; or

19.13.1.2 ✓ Be constructed so that there is a low likelihood of
substantial leakage and have a surface designed to
facilitate decontamination. In either case, the licensee
shall have a method to safely store the sources during
repairs of the pool.

19.13.2 ✓ For licenses initially issued after January 1, 1997, irradiator
pools must have no outlets more than 0.5 meter below the normal
low water level that could allow water to drain out of the pool.
Pipes that have intakes more than 0.5 meter below the normal low
water level and that could act as siphons must have siphon
breakers to prevent the siphoning of pool water.

19.13.3 ✓ A means must be provided to replenish water losses from the pool.

DRAFT

October 10, 1996

1 19.13.4 ✓ A visible indicator must be provided in a clearly visible location
2 to indicate if the pool water level is below the normal low water
3 level or above the normal high water level.
4

5 19.13.5 ✓ Irradiator pools must be equipped with a purification system
6 designed to be capable of maintaining the water during normal
7 operation at a conductivity of 20 microsiemens per centimeter or
8 less and with a clarity so that the sources can be seen clearly.
9

10 19.13.6 ✓ A physical barrier, such as a railing or cover, must be used
11 around or over irradiator pools during normal operation to prevent
12 personnel from accidentally falling into the pool. The barrier may
13 be removed during maintenance, inspection, and service operations.
14

15 19.13.7 ✓ If long-handled tools or poles are used in irradiator pools, the
16 radiation dose rate on the handling areas of the tools may not
17 exceed 0.02 millisievert (2 millirems) per hour.
18

19 RH 19.14 Div 2 ✓ Source Rack Protection.
20

21 19.14.1 ✓ If the product to be irradiated moves on a product conveyor
22 system, the source rack and the mechanism that moves the rack must
23 be protected by a barrier or guides to prevent products and
24 product carriers from hitting or touching the rack or mechanism.
25

26 RH 19.15 Div 2 ✓ Power Failures.
27

28 19.15.1 ✓ If electrical power at a panoramic irradiator is lost for longer
29 than 10 seconds, the sources must automatically return to the

D R A F T

October 10, 1996

1 shielded position.

2
3 19.15.2 ✓ The lock on the door of the radiation room of a panoramic
4 irradiator may not be deactivated by a power failure.

5
6 19.15.3 ✓ During a power failure, the area of any irradiator where sources
7 are located may be entered only when using an operable and
8 calibrated radiation survey meter.

9
10 RH 19.16 *Div 2* ✓ Design Requirements.

11
12 19.16.1 ✓ Irradiators whose construction begins after January 1, 1997, must
13 meet the design requirements of this section.

14
15 19.16.1.1 ✓ Shielding. For panoramic irradiators, the licensee shall
16 design shielding walls to meet generally accepted building
17 code requirements for reinforced concrete and design the
18 walls, wall penetrations, and entranceways to meet the
19 radiation shielding requirements of RH 19.9. If the
20 irradiator will use more than 2×10^{17} becquerels (5 million
21 curies) of activity, the licensee shall evaluate the effects
22 of heating of the shielding walls by the irradiator sources.

23
24 19.16.1.2 ✓ Foundations. For panoramic irradiators, the licensee shall
25 design the foundation, with consideration given to soil
26 characteristics, to ensure it is adequate to support the
27 weight of the facility shield walls.

28
29 19.16.1.3 ✓ Pool integrity. For pool irradiators, the licensee shall

D R A F T

October 10, 1996

design the pool to assure that it is leak resistant, that it is strong enough to bear the weight of the pool water and shipping casks, that a dropped cask would not fall on sealed sources, that all outlets or pipes meet the requirements of RH 19.13.2, and that metal components are metallurgically compatible with other components in the pool.

19.16.1.4

✓ Water handling system. For pool irradiators, the licensee shall verify that the design of the water purification system is adequate to meet the requirements of RH 19.13.5. The system must be designed so that water leaking from the system does not drain to unrestricted areas without being monitored

19.16.1.5

✓ Radiation monitors. For all irradiators, the licensee shall evaluate the location and sensitivity of the monitor to detect sources carried by the product conveyor system as required by RH 19.11.1. The licensee shall verify that the product conveyor is designed to stop before a source on the product conveyor would cause a radiation overexposure to any person. For pool irradiators, if the licensee uses radiation monitors to detect contamination under RH 19.22.2, the licensee shall verify that the design of radiation monitoring systems to detect pool contamination includes sensitive detectors located close to where contamination is likely to concentrate.

19.16.1.6

✓ Source rack. For pool irradiators, the licensee shall verify that there are no crevices on the source or between the

D R A F T

October 10, 1996

1 source and source holder that would promote corrosion on a
2 critical area of the source. For panoramic irradiators, the
3 licensee shall determine that source rack drops due to loss
4 of power will not damage the source rack and that source
5 rack drops due to failure of cables (or alternate means of
6 support) will not cause loss of integrity of sealed sources.
7 For panoramic irradiators, the licensee shall review the
8 design of the mechanism that moves the sources to assure
9 that the likelihood of a stuck source is low and that, if
10 the rack sticks, a means exists to free it with minimal risk
11 to personnel.
12

13 19.16.1.7

✓ Access control. For panoramic irradiators, the licensee
14 shall verify from the design and logic diagram that the
15 access control system will meet the requirements of RH 19.8.
16

17 19.16.1.8

✓ Fire protection. For panoramic irradiators, the licensee
18 shall verify that the number, location, and spacing of the
19 smoke and heat detectors are appropriate to detect fires and
20 that the detectors are protected from mechanical and
21 radiation damage. The licensee shall verify that the design
22 of the fire extinguishing system provides the necessary
23 discharge patterns, densities, and flow characteristics for
24 complete coverage of the radiation room and that the system
25 is protected from mechanical and radiation damage.
26

27 19.16.1.9

✓ Source return. For panoramic irradiators, the licensee shall
28 verify that the source rack will automatically return to the
29 fully shielded position if facility power is lost for more

Note: Chuck Mattson said State statute requires that any document cited must be certified as correct by a notary public; and be readily available. ^{DRAFT} ACI 318-39 was cited as an example, only. Steve

October 10, 1996

than 10 seconds.

19.16.1.10

Seismic. For panoramic irradiators to be built in seismic

§36-39(j)

areas, the licensee shall design the reinforced concrete

radiation shields to retain their integrity in the event of

an earthquake by designing to the seismic requirements of an

appropriate source such as current national standards or

local building codes.

This wording is different but acceptable. See e-mail from Cheryl Trotter.

19.16.1.11

✓ Wiring. For panoramic irradiators, the licensee shall verify

that electrical wiring and electrical equipment in the

radiation room are selected to minimize failures due to

prolonged exposure to radiation.

also from Steve McGuire

RH 19.17 ^{Div 2} Construction Monitoring and Acceptance Testing.

19.17.1 ✓ The requirements of this section must be met for irradiators whose

construction begins after January 1, 1997. The requirements must

be met prior to loading sources.

19.17.1.1

✓ Shielding. For panoramic irradiators, the licensee shall

monitor the construction of the shielding to verify that its

construction meets design specifications and generally

accepted building code requirements for reinforced concrete.

19.17.1.2

✓ Foundations. For panoramic irradiators, the licensee shall

monitor the construction of the foundations to verify that

their construction meets design specifications.

D R A F T

October 10, 1996

19.17.1.3

✓ Pool integrity. For pool irradiators, the licensee shall verify that the pool meets design specifications and shall test the integrity of the pool. The licensee shall verify that outlets and pipes meet the requirements of RH 19.13.2.

19.17.1.4

✓ Water handling system. For pool irradiators, the licensee shall verify that the water purification system, the conductivity meter, and the water level indicators operate properly.

19.17.1.5

✓ Radiation monitors. For all irradiators, the licensee shall verify the proper operation of the monitor to detect sources carried on the product conveyor system and the related alarms and interlocks required by RH 19.11.1. For pool irradiators, the licensee shall verify the proper operation of the radiation monitors and the related alarm if used to meet RH 19.22.2. For underwater irradiators, the licensee shall verify the proper operation of the over-the-pool monitor, alarms, and interlocks required by RH 19.11.2.

19.17.1.6

✓ Source rack. For panoramic irradiators, the licensee shall test the movement of the source racks for proper operation prior to source loading, and testing must include source rack lowering due to simulated loss of power. For all irradiators with product conveyor systems, the licensee shall observe and test the operation of the conveyor system to assure that the requirements in RH 19.14 are met for protection of the source rack and the mechanism that moves the rack. Testing must include tests of any limit switches

D R A F T

October 10, 1996

and interlocks used to protect the source rack and mechanism that moves the rack from moving product carriers.

19.17.1.7 ✓ Access control. For panoramic irradiators, the licensee shall test the completed access control system to assure that it functions as designed and that all alarms, controls, and interlocks work properly.

19.17.1.8 ✓ Fire protection. For panoramic irradiators, the licensee shall test the ability of the heat and smoke detectors to detect a fire, to activate alarms, and to cause the source rack to automatically become fully shielded. The licensee shall test the operability of the fire extinguishing system.

19.17.1.9 ✓ Source return. For panoramic irradiators, the licensee shall demonstrate that the source racks can be returned to their fully shielded positions without offsite power.

19.17.1.10 ✓ Computer systems. For panoramic irradiators that use a computer system to control the access control system, the licensee shall verify that the access control system will operate properly if offsite power is lost and shall verify that the computer has security features that prevent an irradiator operator from commanding the computer to override the access control system when it is required to be operable.

19.17.1.11 ✓ Wiring. For panoramic irradiators, the licensee shall verify that the electrical wiring and electrical equipment that

D R A F T

October 10, 1996

and interlocks used to protect the source rack and mechanism that moves the rack from moving product carriers.

19.17.1.7 ✓ Access control. For panoramic irradiators, the licensee shall test the completed access control system to assure that it functions as designed and that all alarms, controls, and interlocks work properly.

19.17.1.8 ✓ Fire protection. For panoramic irradiators, the licensee shall test the ability of the heat and smoke detectors to detect a fire, to activate alarms, and to cause the source rack to automatically become fully shielded. The licensee shall test the operability of the fire extinguishing system.

19.17.1.9 ✓ Source return. For panoramic irradiators, the licensee shall demonstrate that the source racks can be returned to their fully shielded positions without offsite power.

19.17.1.10 ✓ Computer systems. For panoramic irradiators that use a computer system to control the access control system, the licensee shall verify that the access control system will operate properly if offsite power is lost and shall verify that the computer has security features that prevent an irradiator operator from commanding the computer to override the access control system when it is required to be operable.

19.17.1.11 ✓ Wiring. For panoramic irradiators, the licensee shall verify that the electrical wiring and electrical equipment that

DRAFT

October 10, 1996

were installed meet the design specifications.

✓
Operation of Irradiators

RH 19.18 *Div 2*
Training.

19.18.1 ✓ Before an individual is permitted to operate an irradiator without a supervisor present, the individual must be instructed in:

19.18.1.1 ✓ The fundamentals of radiation protection applied to irradiators (including the differences between external radiation and radioactive contamination, units of radiation dose, Department dose limits, why large radiation doses must be avoided, how shielding and access controls prevent large doses, how an irradiator is designed to prevent contamination, the proper use of survey meters and personnel dosimeters, other radiation safety features of an irradiator, and the basic function of the irradiator);

19.18.1.2 ✓ The requirements of Parts 4, 10 and 19 of these regulations that are relevant to the irradiator;

19.18.1.3 ✓ The operation of the irradiator;

19.18.1.4 ✓ Those operating and emergency procedures listed in RH 19.19 that the individual is responsible for performing; and

19.18.1.5 ✓ Case histories of accidents or problems involving

D R A F T

October 10, 1996

1 irradiators.

2

3 19.18.2 ✓ Before an individual is permitted to operate an irradiator without

4 a supervisor present, the individual shall pass a written test on

5 the instruction received consisting primarily of questions based

6 on the licensee's operating and emergency procedures that the

7 individual is responsible for performing and other operations

8 necessary to safely operate the irradiator without supervision.

9

10 19.18.3 ✓ Before an individual is permitted to operate an irradiator without

11 a supervisor present, the individual must have received on-the-job

12 training or simulator training in the use of the irradiator as

13 described in the license application. The individual shall also

14 demonstrate the ability to perform those portions of the operating

15 procedures that he or she is to perform.

16

17 19.18.4 ✓ The licensee shall conduct safety reviews for irradiator operators

18 at least annually. The licensee shall give each operator a brief

19 written test on the information. Each safety review must include,

20 to the extent appropriate, each of the following:

21

22 19.18.4.1 ✓ Changes in operating and emergency procedures since the last

23 review, if any;

24

25 19.18.4.2 ✓ Changes in regulations and license conditions since the last

26 review, if any;

27

28 19.18.4.3 ✓ Reports on recent accidents, mistakes, or problems that have

29 occurred at irradiators, if any;

D R A F T

October 10, 1996

19.18.4.4

✓ Relevant results of inspections of operator safety performance;

19.18.4.5

✓ Relevant results of the facility's inspection and maintenance checks; and

19.18.4.6

✓ A drill to practice an emergency or abnormal event procedure.

19.18.5

✓ The licensee shall evaluate the safety performance of each irradiator operator at least annually to ensure that regulations, license conditions, and operating and emergency procedures are followed. The licensee shall discuss the results of the evaluation with the operator and shall instruct the operator on how to correct any mistakes or deficiencies observed.

19.18.6

✓ Individuals who will be permitted unescorted access to the radiation room of the irradiator or the area around the pool of an underwater irradiator, but who have not received the training required for operators and the radiation safety officer, shall be instructed and tested in any precautions they should take to avoid radiation exposure, any procedures or parts of procedures listed in RH 19.19 that they are expected to perform or comply with, and their proper response to alarms required in this part. Tests may be oral.

19.18.7

✓ Individuals who must be prepared to respond to alarms required by RH 19.8.2, 19.8.9, 19.10.1, 19.11.1, 19.11.2, and 19.22.2 shall be trained and tested on how to respond. Each individual shall be

D R A F T

October 10, 1996

retested at least once a year. Tests may be oral.

Div 2
RH 19.19 Operating and Emergency Procedures.

19.19.1 The licensee shall have and follow written operating procedures for:

19.19.1.1 Operation of the irradiator, including entering and leaving the radiation room;

19.19.1.2 Use of personnel dosimeters;

19.19.1.3 Surveying the shielding of panoramic irradiators;

19.19.1.4 Monitoring pool water for contamination while the water is in the pool and before release of pool water to unrestricted areas;

19.19.1.5 Leak testing of sources;

19.19.1.6 Inspection and maintenance checks required by RH 19.23;

19.19.1.7 Loading, unloading, and repositioning sources, if the operations will be performed by the licensee; and

19.19.1.8 Inspection of movable shielding required by RH 19.8.8, if applicable.

19.19.2 The licensee shall have and follow emergency or abnormal event.

D R A F T

October 10, 1996

retested at least once a year. Tests may be oral.

Div 2
RH 19.19 Operating and Emergency Procedures.

19.19.1 The licensee shall have and follow written operating procedures for:

19.19.1.1 Operation of the irradiator, including entering and leaving the radiation room;

19.19.1.2 Use of personnel dosimeters;

19.19.1.3 Surveying the shielding of panoramic irradiators;

19.19.1.4 Monitoring pool water for contamination while the water is in the pool and before release of pool water to unrestricted areas;

19.19.1.5 Leak testing of sources;

19.19.1.6 Inspection and maintenance checks required by RH 19.23;

19.19.1.7 Loading, unloading, and repositioning sources, if the operations will be performed by the licensee; and

19.19.1.8 Inspection of movable shielding required by RH 19.8.8, if applicable.

19.19.2 The licensee shall have and follow emergency or abnormal event

D R A F T

October 10, 1996

procedures, appropriate for the irradiator type, for:

- 19.19.2.1 ✓ Sources stuck in the unshielded position;
- 19.19.2.2 ✓ Personnel overexposures;
- 19.19.2.3 ✓ A radiation alarm from the product exit portal monitor or pool monitor;
- 19.19.2.4 ✓ Detection of leaking sources, pool contamination, or alarm caused by contamination of pool water;
- 19.19.2.5 ✓ A low or high water level indicator, an abnormal water loss, or leakage from the source storage pool;
- 19.19.2.6 ✓ A prolonged loss of electrical power;
- 19.19.2.7 ✓ A fire alarm or explosion in the radiation room;
- 19.19.2.8 ✓ An alarm indicating unauthorized entry into the radiation room, area around the pool, or another alarmed area;
- 19.19.2.9 ✓ Natural phenomena, including an earthquake, a tornado, flooding, or other phenomena as appropriate for the geographical location of the facility; and
- 19.19.2.10 ✓ The jamming of automatic conveyor systems.
- 19.19.3 ✓ The licensee may revise operating and emergency procedures without

DRAFT

October 10, 1996

1 Department approval only if all of the following conditions are
2 met:

3
4 19.19.3.1 ✓ The revisions do not reduce the safety of the facility,

5
6 19.19.3.2 ✓ The revisions are consistent with the outline or summary of
7 procedures submitted with the license application,

8
9 19.19.3.3 ✓ The revisions have been reviewed and approved by the
10 radiation safety officer, and

11
12 19.19.3.4 ✓ The users or operators are instructed and tested on the
13 revised procedures before they are put into use.

14
15 RH 19.20 *Div 2* Personnel Monitoring.

16
17 19.20.1 ✓ Irradiator operators shall wear either a film badge or a
18 thermoluminescent dosimeter (TLD) while operating a panoramic
19 irradiator or while in the area around the pool or an underwater
20 irradiator. The film badge or TLD processor must be accredited by
21 the National Voluntary Laboratory Accreditation Program for high
22 energy photons in the normal and accidental dose ranges (see RH
23 4.17.3). Each film badge or TLD must be assigned to and worn by
24 only one individual. Film badges must be processed at least
25 monthly, and TLD's must be processed at least quarterly.

26
27 19.20.2 ✓ Other individuals who enter the radiation room of a panoramic
28 irradiator shall wear a dosimeter, which may be a pocket
29 dosimeter. For groups of visitors, only two people who enter the

D R A F T

October 10, 1996

radiation room are required to wear dosimeters. If pocket dosimeters are used to meet the requirements of this paragraph, a check of their response to radiation must be done at least annually. Acceptable dosimeters must read within ± 30 percent of the true radiation dose.

Div 2
RH 19.21 Radiation Surveys.

19.21.1 ✓ A radiation survey of the area outside the shielding of the radiation room of a panoramic irradiator must be conducted with the sources in the exposed position before the facility starts to operate. A radiation survey of the area above the pool of pool irradiators must be conducted after the sources are loaded but before the facility starts to operate. Additional radiation surveys of the shielding must be performed at intervals not to exceed 3 years and before resuming operation after addition of new sources or any modification to the radiation room shielding or structure that might increase dose rates.

19.21.2 ✓ If the radiation levels specified in RH 19.9 are exceeded, the facility must be modified to comply with the requirements in RH 19.9.

19.21.3 ✓ Portable radiation survey meters must be calibrated at least annually to an accuracy of ± 20 percent for the gamma energy of the sources in use. The calibration must be done at two points on each scale or, for digital instruments at one point per decade over the range that will be used. Portable radiation survey meters must be of a type that does not saturate and read zero at high radiation

DRAFT

October 10, 1996

dose rates.

19.21.4 ✓ Water from the irradiator pool, other potentially contaminated liquids, and sediments from pool vacuuming must be monitored for radioactive contamination before release to unrestricted areas. Radioactive concentrations must not exceed those specified in Part 4, Appendix B, Table I, "Annual Limits on Intakes (ALI's) and Derived Air Concentrations (DAC's), or Table III, "Release to sewers".

19.21.5 Before releasing resins for unrestricted use, they must be monitored before release in an area with a background level less than 0.5 microsievert (0.05 millirem) per hour. The resins may be released only if the survey does not detect radiation levels above background levels. The survey meter used must be capable of detecting radiation levels of 0.5 microsievert (0.05 millirem) per hour.

§36.57(e)
This was omitted originally - a glitch in computer according to Chuck Mattson. Steve 10/10/96
RH 19.22 ✓ Detection of Leaking Sources.

19.22.1 ✓ Each dry-source-storage sealed source must be tested for leakage at intervals not to exceed 6 months using a leak test kit or method approved by the U.S. Nuclear Regulatory Commission or an Agreement State. In the absence of a certificate from a transferor that a test has been made within the 6 months before the transfer, the sealed source may not be used until tested. The test must be capable of detecting the presence of 200 becquerels (0.005 microcurie) of radioactive material and must be performed by a person approved by the U.S. Nuclear Regulatory Commission or an

Word "radiation" is missing as shown but repeat of word is unimportant.

DRAFT

October 10, 1996

1 Agreement State to perform the test.

2
3 19.22.2 ✓ For pool irradiators, sources may not be put into the pool unless
4 the licensee tests the sources for leaks or has a certificate from
5 a transferor that a leak test has been done within the 6 months
6 before the transfer. Water from the pool must be checked for
7 contamination each day the irradiator operates. This check may be
8 done either by using a radiation monitor on a pool water
9 circulating system or by analysis of a sample of pool water. If a
10 check for contamination is done by analysis of a sample of pool
11 water, the results must be available within 24 hours. If the
12 licensee uses a radiation monitor on a pool water circulating
13 system, the detection of above normal radiation levels must
14 activate an alarm. The alarm set-point must be set as low as
15 practical, but high enough to avoid false alarms. The licensee may
16 reset the alarm set-point to a higher level if necessary to
17 operate the pool water purification system to clean up
18 contamination in the pool if specifically provided for in written
19 emergency procedures.

20
21 19.22.3 ✓ If a leaking source is detected, the licensee shall arrange to
22 remove the leaking source from service and have it decontaminated,
23 repaired, or disposed of by a U.S. Nuclear Regulatory Commission
24 or Agreement State licensee that is authorized to perform these
25 functions. The licensee shall promptly check its personnel,
26 equipment, facilities, and irradiated product for radioactive
27 contamination. No product may be shipped until the product has
28 been checked and found free of contamination. If a product has
29 been shipped that may have been inadvertently contaminated, the

DRAFT

October 10, 1996

licensee shall arrange to locate and survey that product for contamination. If any personnel are found to be contaminated, decontamination must be performed promptly. If contaminated equipment, facilities, or products are found, the licensee shall arrange to have them decontaminated or disposed of by a U.S. Nuclear Regulatory Commission or Agreement State licensee that is authorized to perform these functions. If a pool is contaminated, the licensee shall arrange to clean the pool until the contamination levels do not exceed the appropriate concentration in Part 4, Appendix B, Table III. (See RH 4.52 and 4.53 of these regulations for notification and reporting requirements.)

Done
RH 19.23 Inspection and Maintenance.

19.23.1 ✓ The licensee shall perform inspection and maintenance checks that include, as a minimum, each of the following at the frequency specified in the license or license application:

19.23.1.1 ✓ Operability of each aspect of the access control system required by RH 19.8.

19.23.1.2 ✓ Functioning of the source position indicator required by RH 19.12.2.

19.23.1.3 ✓ Operability of the radiation monitor for radioactive contamination in pool water required by RH 19.22.2, using a radiation check source, if applicable.

19.23.1.4 ✓ Operability of the over-pool radiation monitor at underwater

DRAFT

October 10, 1996

- 1 irradiators as required by RH 19.11.2.
- 2
- 3 19.23.1.5 ✓ Operability of the product exit monitor required by
- 4 RH 19.11.1.
- 5
- 6 19.23.1.6 ✓ Operability of the emergency source return control required
- 7 by RH 19.12.3.
- 8
- 9 19.23.1.7 ✓ Leak-tightness of systems through which pool water
- 10 circulates (visual inspection).
- 11
- 12 19.23.1.8 ✓ Operability of the heat and smoke detectors and extinguisher
- 13 system required by RH 19.10 (but without turning
- 14 extinguishers on).
- 15
- 16 19.23.1.9 ✓ Operability of the means of pool water replenishment
- 17 required by RH 19.13.3.
- 18
- 19 19.23.1.10 ✓ Operability of the indicators of high and low pool water
- 20 levels required by RH 19.13.4.
- 21
- 22 19.23.1.11 ✓ Operability of the intrusion alarm required by RH 19.8.9, if
- 23 applicable.
- 24
- 25 19.23.1.12 ✓ Functioning and wear of the system, mechanisms and cables
- 26 used to raise and lower sources.
- 27
- 28 19.23.1.13 ✓ Condition of the barrier to prevent products from hitting
- 29 the sources or source mechanism as required by RH 19.14.

DRAFT

October 10, 1996

1 19.23.1.14 ✓ Amount of water added to the pool to determine if the pool
2 is leaking.

4 19.23.1.15 ✓ Electrical wiring on required safety systems for radiation
5 damage.

7 19.23.1.16 ✓ Pool water conductivity measurements and analysis as
8 required by RH 19.24.2.

10 19.23.2 ✓ Malfunctions and defects found during inspection and maintenance
11 checks must be repaired without undue delay.

13 RH 19.24 Div 2 Pool Water Purity.

15 19.24.1 ✓ Pool water purification system must be run sufficiently to
16 maintain the conductivity of the pool water below 20 microsiemens
17 per centimeter under normal circumstances. If pool water
18 conductivity rises above 20 microsiemens per centimeter, the
19 licensee shall take prompt actions to lower the pool water
20 conductivity and shall take corrective actions to prevent future
21 recurrences.

23 19.24.2 ✓ The licensee shall measure the pool water conductivity frequently
24 enough, but no less than weekly, to assure that the conductivity
25 remains below 20 microsiemens per centimeter. Conductivity meters
26 must be calibrated at least annually.

28 RH 19.25 Div 2 Attendance During Operations.

DRAFT

October 10, 1996

1 19.25.1 ✓ Both an irradiator operator and at least one individual, who is
2 trained on how to respond and prepared to promptly render or
3 summon assistance if the access control alarm sounds, shall be
4 present onsite.

5
6 19.25.1.1 ✓ Whenever the irradiator is operated using an automatic
7 product conveyor system; and

8
9 19.25.1.2 ✓ Whenever the product is moved into or out of the radiation
10 room when the irradiator is operated in a batch mode.

11
12 19.25.2 ✓ At a panoramic irradiator at which static irradiations (no
13 movement of the product) are occurring, a person who has received
14 the training on how to respond to alarms described in RH 19.18.7
15 must be onsite.

16
17 19.25.3 ✓ At an underwater irradiator, an irradiator operator must be
18 present at the facility whenever the product is moved into or out
19 of the pool. Individuals who move the product into or out of the
20 pool of an underwater irradiator need not be qualified as
21 irradiator operators; however, they must have received the
22 training described in RH 19.18.6 and 19.18.7. Static irradiations
23 may be performed without a person present at the facility.

24
25 RH 19.26 Div 2 ✓ Entering and Leaving the Irradiation Room.

26
27 19.26.1 ✓ Upon first entering the radiation room of a panoramic irradiator
28 after an irradiation, the irradiator operator shall use a survey
29 meter to determine that the source has returned to its fully

DRAFT

October 10, 1996

shielded position. The operator shall check the functioning of the survey meter with a radiation check source prior to entry.

19.26.2 ✓ Before exiting from and locking the door to the radiation room of a panoramic irradiator prior to a planned irradiation, the irradiator operator shall:

19.26.2.1 ✓ Visually inspect the entire radiation room to verify that no one else is in it; and

19.26.2.2 ✓ Activate a control in the radiation room that permits the sources to be moved from the shielded position only if the door to the radiation room is locked within a preset time after setting the control.

19.26.3 ✓ During a power failure, the area around the pool of an underwater irradiator may not be entered without using an operable and calibrated radiation survey meter unless the over-the-pool monitor required by RH 19.11.2 is operating with backup power.

RH 19.27 *Div 2* ✓ Irradiation of Explosive or Flammable Materials.

19.27.1 ✓ Irradiation of explosive material is prohibited unless the licensee has received prior written authorization from the Department. Authorization will not be granted unless the licensee can demonstrate that detonation of the explosive would not rupture the sealed sources, injure personnel, damage safety systems, or cause radiation overexposures of personnel.

DRAFT

October 10, 1996

1 19.27.2 ✓ Irradiation of more than small quantities of flammable material
2 (flash point below 140°C) is prohibited in panoramic irradiators
3 unless the licensee has received prior written authorization from
4 the Department. Authorization will not be granted unless the
5 licensee can demonstrate that a fire in the radiation room could
6 be controlled without damage to the sealed sources or safety
7 systems and without radiation overexposures of personnel.
8

9 **Records**

10
11 RH 19.28 ✓ Records and Retention Periods.
12

13 19.28.1 ✓ The licensee shall maintain the following records at the
14 irradiator for the periods specified:
15

16 19.28.1.1 A copy of the license, license conditions, documents
17 ✓ incorporated into a license by reference, and amendments
18 thereto until superseded by new documents or until the
19 Department terminates the license for documents not
20 superseded.
21

22 19.28.1.2 ✓ Records of each individual's training, tests, and safety
23 reviews provided to meet the requirements of RH 19.18.1,
24 19.18.2, 19.18.3, 19.18.4, 19.18.6, and 19.18.7 until 3
25 years after the individual terminates work.
26

27 19.28.1.3 ✓ Records of the annual evaluations of the safety performance
28 of irradiator operators required by RH 19.18.5 for 3 years
29 after the evaluation.

DRAFT

October 10, 1996

- 1 19.28.1.4 ✓ A copy of the current operating and emergency procedures
2 required by RH 19.19 until superseded or the Department
3 terminates the license. Records of the radiation safety
4 officer's review and approval of changes in procedures as
5 required by RH 19.19.3.3 retained for 3 years from the date
6 of the change.
- 7
- 8 19.28.1.5 ✓ Film badge and TLD results required by RH 19.20 in
9 accordance with RH 4.46 of these regulations.
- 10
- 11 19.28.1.6 ✓ Records of radiation surveys required by RH 19.21 for 3
12 years from the date of the survey.
- 13
- 14 19.28.1.7 ✓ Records of radiation survey meter calibrations required by
15 RH 19.21.3 and pool water conductivity meter calibrations
16 required by RH 19.24.2 until 3 years from the date of
17 calibration.
- 18
- 19 19.28.1.8 ✓ Records of the results of leak tests required by RH 19.22.1
20 and the results of contamination checks required by RH
21 19.22.2 for 3 years from the date of each test.
- 22
- 23 19.28.1.9 ✓ Records of inspection and maintenance checks required by
24 RH 19.23 for 3 years.
- 25
- 26 19.28.1.10 ✓ Records of major malfunctions, significant defects,
27 operating difficulties or irregularities, and major
28 operating problems that involve required radiation safety
29 equipment for 3 years after repairs are completed.

D R A F T

October 10, 1996

1 19.28.1.11 ✓ Records of the receipt, transfer, and disposal of all
2 licensed sealed sources as required by RH 3.22 and RH 4.48
3 of these regulations.

4
5 19.28.1.12 ✓ Records on the design checks required by RH 19.16 and the
6 construction control checks as required by RH 19.17 until
7 the license is terminated. The records must be signed and
8 dated. The title or qualification of the person signing must
9 be included.

10
11 19.28.1.13 ✓ Records related to decommissioning of the irradiator as
12 § 36.8(m) required by RH 3.16.6.8 of these Regulations.

13 This was originally left out because Part 3, Record
14 RH 19.29 Reports. Keeping was in process and Chuck needed
15 the reference. Steve 10/10/96

16 19.29.1 ✓ In addition to the reporting requirements in other parts of the
17 regulations, the licensee shall report the following events:

18
19 19.29.1.1 ✓ Source stuck in an unshielded position.

20
21 19.29.1.2 ✓ Any fire or explosion in a radiation room.

22
23 19.29.1.3 ✓ Damage to the source racks.

24
25 19.29.1.4 ✓ Failure of the cable or drive mechanism used to move the
26 source racks.

27
28 19.29.1.5 ✓ Inoperability of the access control system.

29

D R A F T

October 10, 1996

- 1 19.29.1.6 ✓ Detection of radiation source by the product exit monitor.
2
3 19.29.1.7 ✓ Detection of radioactive contamination attributable to
4 licensed radioactive material.
5
6 19.29.1.8 ✓ Structural damage to the pool liner or walls.
7
8 19.29.1.9 ✓ Abnormal water loss or leakage from the source storage pool.
9
10 19.29.1.10 ✓ Pool water conductivity exceeding 100 microsiemens per
11 centimeter.
12
13 19.29.2 ✓ The report must include a telephone report within 24 hours as
14 described in RH 4.52.2, and a written report within 30 days as
15 described in RH 4.53.1.2 of these regulations.

16 Subpart F - Enforcement (elsewhere).

(FVL) RLB
PHL
SLD

EXECUTIVE TASK MANAGEMENT SYSTEM

<<< PRINT SCREEN UPDATE FORM >>>

TASK # - 6S246

DATE- 10/03/96

MAIL CTRL. - 1996

TASK STARTED - 10/02/96

TASK DUE - 10/22/96

TASK COMPLETED - / /

TASK DESCRIPTION - COLORADO REGS - LICENSING AND RADIATION SAFETY
REQUIREMENTS FOR IRRADIATORS FOR REVIEW

REQUESTING OFF. - RIV

REQUESTER - C. HACKNEY

WITS -

0 FYP - N

PROG.- SNS

PERSON -

STAFF LEAD - SNS

PROG. AREA -

PROJECT STATUS -

OSP DUE DATE: 10/23/96

PLANNED ACC. - N

LEVEL CODE - 1