

AUG 16 1985

Docket No. 50-266

Docket No. 50-301

Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Vice President
Nuclear Power Department
231 West Michigan, Room 308
Milwaukee, WI 53201

Gentlemen:

We have completed our review of the July 12, 1985, revisions to the Point Beach Nuclear Plant Emergency Plan. Our review indicated that your plan changes do not downgrade the effectiveness of your emergency plan.

Please be reminded that 10 CFR Part 50.54(q) requires NRC approval of any changes to your plan which may decrease the effectiveness of the plan. However, if your safety review indicates no decrease in emergency preparedness, then changes can be made without NRC approval. In all cases, you should furnish copies of each proposed change to the NRC in accordance with 10 CFR Part 50.54(q). Also, any changes to the Emergency Plan Implementing Procedures should be made in accordance with the requirements of 10 CFR Part 50, Appendix E, Section V (Implementing Procedures).

Should you have any questions regarding this letter, please contact Mr. William Snell of my staff at (312) 790-5513.

Sincerely,

W. D. Shafer, Chief
Emergency Preparedness and
Radiological Protection Branch

cc: J. J. Zach, Plant Manager
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
John J. Duffy, Chief
Boiler Section
Ness Flores, Chairperson
Wisconsin Public Service
Commission
Peter Anderson, Wisconsin's
Environmental Decade
W. Weaver, FEMA, Region V
D. Matthews, EPB

RIII
W. Snell
08/14/85

RIII
Phil
W. Snell for

RIII
Jack
for

RIII
Shafer

8508230051 850816
PDR ADOCK 05000266
F PDR

IE35
1/0