

**TEXAS UTILITIES GENERATING COMPANY**

SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

WILLIAM G. COUNCIL  
EXECUTIVE VICE PRESIDENT

August 19, 1985

Director of Nuclear Reactor Regulation  
Attention: Mr. Vince S. Noonan, Director  
Comanche Peak Project  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
NRC GENERIC LETTER 83-28

REF: J. W. Beck letter to V. S. Noonan  
dated June 7, 1985


Dear Mr. Noonan:

The referenced letter provided the CPSES response to additional NRC questions pertaining to Generic Letter 83-28, "Required Action Based on Generic Implications of Salem ATWS Events". Specifically, NRC Item 3.1.3 (Post-Maintenance Testing of the Reactor Trip System Components) requested information concerning test and maintenance programs that degrade rather than enhance safety.

As mentioned in the referenced response, CPSES endorses WCAP-10271 "Evaluation of Surveillance Frequencies and Out of Service Times for the Reactor Protection Instrumentation System", and its Supplement #1. The WCAP and its supplement address test and maintenance programs that may unnecessarily degrade safety. Proposed changes to the technical specifications are being withheld pending CPSES review of the NRC Safety Evaluation Report (SER) for the WCAP.

In addition, based on the CPSES ongoing review of plant technical specifications, no additional post-maintenance test programs for reactor trip system components have been identified that may degrade safety.

Very truly yours,



W. G. Council

RWH/grr

8508230230 850819  
PDR ADOCK 05000445  
A PDR

A055  
1/0