



GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST. FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 635-6094 346-8651

July 29, 1985

RBG- 21,716

File Nos. G9.5, G9.8.2.16

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station - Unit 1
Docket No. 50-458

Enclosed for your review are Gulf States Utilities Company proposed changes to the River Bend Station Technical Specifications. These changes are as the result of the Transamerica Delaval Inc. diesel generator final review and were reviewed by your Staff during recent discussions.

Sincerely,

J. E. Booker

J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/WJR/JEF/je

Enclosure (1)

8508280042 850729
PDR ADOCK 05000458
A PDR

13001
11

ENCLOSURE 1

SURVEILLANCE REQUIREMENTS (Continued)

5. Verifying the diesel generator is synchronized, loaded to 3030-3130 kw** for diesel generators 1A and 1B and 2500-2600 kw** for diesel generator 1C in less than or equal to 60 seconds, and operates with this load for at least 60 minutes.
6. Verifying the diesel generator is aligned to provide standby power to the associated emergency busses.
7. Verifying the pressure in all diesel generator air start receivers to be greater than or equal to 160 psig.
- b. At least once per 24 hours by verifying for diesel generator 1A and 1B that the lube oil circulating pump is operating.
- c. By removing accumulated water:
 1. From the day tank at least once per 31 days and after each occasion when the diesel is operated for greater than 1 hour, and
 2. From the storage tank at least once per 31 days.
- d. By sampling new fuel oil in accordance with ASTM D4057-81 prior to addition to the storage tanks and:
 1. By verifying in accordance with the tests specified in ASTM D975-81, prior to addition to the storage tanks, that the sample has:
 - a) An API Gravity of within 0.3 degrees at 60°F or a specific gravity of within 0.0016 at 60/60°F, when compared to the supplier's certificate, or an absolute specific gravity at 60/60°F of greater than or equal to 0.83 but less than or equal to 0.89, or an API gravity at 60°F of greater than or equal to 27 degrees but less than or equal to 39 degrees.
 - b) A kinematic viscosity at 40°C of greater than or equal to 1.9 centistokes, but less than or equal to 4.1 centistokes, if gravity was not determined by comparison with the supplier's certification.
 - c) A flash point equal to or greater than 125°F, and
 - d) A clear and bright appearance with proper color when tested in accordance with ASTM D4176-82.

~~**This band is meant as guidance to avoid routine overloading of the engine. Loads in excess of this band for special testing under direct monitoring of the manufacturer or Momentary variations due to changing bus loads shall not invalidate the test.~~
(transients)

SURVEILLANCE REQUIREMENTS (Continued)

2. By verifying an antioxidant type diesel fuel oil stabilizer is added to new fuel added to the storage tanks in accordance with manufacturer's recommendations.
 3. By verifying within 31 days of obtaining the sample that the other properties specified in Table 1 of ASTM D975-81 are met when tested in accordance with ASTM D975-81, except that the analysis for sulfur may be performed in accordance with ASTM D1552-79 or ASTM D2622-82.
- e. At least once every 31 days by obtaining a sample of fuel oil from the storage tanks in accordance with ASTM D2276-78 and verifying that total particulate contamination is less than 10 mg/liter when checked in accordance with ASTM D2276-78, Method A.
- f. At least once per 18 months, during shutdown, by:
1. Subjecting the diesel to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.
 2. Verifying the diesel generator capability to reject a load of greater than or equal to 917.5 kw for diesel generator 1A, greater than or equal to 509.2 kw for diesel generator 1B, and greater than or equal to 1995 kw for diesel generator 1C while maintaining voltage at 4160 ± 420 volts and frequency at 60 ± 1.2 Hz, and while maintaining engine speed less than 75% of the difference between nominal speed and the overspeed trip setpoint or 15% above nominal, whichever is less.
 3. Verifying the diesel generator capability to reject a load of 3030-3130 kw** for diesel generators 1A and 1B and 2500-2600 kw** for diesel generator 1C without tripping. The generator voltage shall not exceed 4784 volts during and following the load rejection.
 4. Simulating a loss of offsite power by itself, and:
 - a) For divisions I and II:
 - 1) Verifying deenergization of the emergency busses and load shedding from the emergency busses.

~~**This band is meant as guidance to avoid routine overloading of the engine. Loads in excess of this band for special testing under direct monitoring of the manufacturer or momentary variations due to changing bus loads shall not invalidate the test.~~ (transients)

SURVEILLANCE REQUIREMENTS (Continued)

- b) For division III:
- 1) Verifying de-energization of the emergency bus.
 - 2) Verifying the diesel generator starts on the auto-start signal, energizes the emergency bus with its permanently connected loads within 10 seconds, energizes the auto-connected loads through the sequencing logic and operates for greater than or equal to 5 minutes while its generator is loaded with the emergency loads. After energization, the steady-state voltage and frequency of the emergency bus shall be maintained at 4160 ± 420 volts and 60 ± 1.2 Hz during this test.
7. Verifying that all automatic diesel generator trips are automatically bypassed upon an ECCS actuation signal except engine overspeed and generator differential current.
 8. Verifying the diesel generator operates for at least 24 hours. During the first 22 hours of this test, the diesel generator shall be loaded to 3030-3130** kw for diesel generators 1A and 1B and 2500-2600** kw for diesel generator 1C. During the remaining 2 hours of this test, the diesel generator shall be loaded to 3030-3130** kw for diesel generator 1A and 1B and 2750-2850** kw for diesel generator 1C. The generator voltage and frequency shall be 4160 ± 420 volts and 60 ± 1.2 Hz within 10 seconds after the start signal; the steady-state generator voltage and frequency shall be maintained within these limits during this test. Within 5 minutes after completing this 24-hour test, perform Surveillance Requirement 4.8.1.1.2.f.4.a)2) and b)2)*.
 9. Verifying that the auto-connected loads to each diesel generator do not exceed 3130 kw for diesel generator 1A and 1B and 2600 kw for diesel generator 1C.
 10. Verifying the diesel generator's capability to:
 - a) Synchronize with the offsite power source, while the generator is loaded with its emergency loads, upon a simulated restoration of offsite power,
 - b) Transfer its loads to the offsite power source, and
 - c) Be restored to its standby status.

*If Surveillance Requirements 4.8.1.1.2.f.4.a)2) and b)2) are not satisfactorily completed, it is not necessary to repeat the preceding 24 hour test. Instead, perform Surveillance Requirement 4.8.1.1.2.a.5 prior to repeating Surveillance Requirements 4.8.1.1.2.f.4.a)2) and b)2) for the appropriate diesel.

~~**This band is meant as guidance to avoid routine overloading of the engine. Loads in excess of this band for special testing under direct monitoring of the manufacturer or momentary variations due to changing bus loads shall not invalidate the test.~~

transients