

FAC NAME/ADDRESS (Include
City Name/Location if different)
FAC NAME UTILITIES (MILLSTONE)
ADDRESS NORTHEAST UTILITIES SERVICE CO
4022 FERRY ROAD
WATERFORD CT 06333
FACILITY UTILITIES (MILLSTONE)
LOCATION WATERFORD CT 06141-0270
ATTN: RONALD G. CHEVALIER, VP

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)
CT0003263
PERMIT NUMBER
VIC 5
DISCHARGE NUMBER
MONITORING PERIOD
YEAR MO DAY TO YEAR MO DAY
93 06 01 TO 93 06 30
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

MAJOR (SUHR 2) Form Approved
F - FINAL OMB No. 2040-0004
#3 HEAT EXCHANG (SERVICE WATER
EFFLUENT
*** NO DATA [] ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0 1	SAMPLE MEASUREMENT	*****	*****		*****	*****	69	(15)		09/02/93	WEEKLY INSTAN
EFFLUENT GROSS VALU FLOW, IN CONDUIT OR THRU TREATMENT PLAN 50050 1 0 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	100 MAXIMUM	DEG.F			
EFFLUENT GROSS VALU CHLORINE, FREE AVAILABLE 50064 1 0 1	SAMPLE MEASUREMENT	*****	43.2	(03)	*****	*****	*****			09/02/93	WEEKLY INSTAN
	PERMIT REQUIREMENT	*****	43.2 DAILY MX	MGD	*****	*****	*****	****			PERMIT
	SAMPLE MEASUREMENT	*****	*****		*****	*****	0.25	(19)	1	07/30	GR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.25 DAILY MX	MG/L			WEEKLY GRAB
	SAMPLE MEASUREMENT						2.0		3	10/30	GR
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER R.G. CHEVALIER VICE PRESIDENT TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIG NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT R.G. Chevalier	TELEPHONE 03 665-0315		DATE 93 08 02		
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

9611140100 961030
PDR ADOCK 05000336
R PDR

NAME/Location (if different)
NAME N.E. UTILITIES (MILLSTONE)
ADDRESS NORTHEAST UTILITIES SERVICE CO
ROPE FERRY ROAD
WATERFORD CT 06385
CITY N.E. UTILITIES (MILLSTONE)
CATION WATERFORD CT 06141-0270
TIN: DONALD G. CHEVALIER, VP

NATIONAL POLLUTANT DISCHARGE ESTIMATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

CT0003263 035 1

PERMIT NUMBER

DISCHARGE NUMBER

MONITORING PERIOD

YEAR MO DAY TO YEAR MO DAY
93 06 01 TO 93 06 30


(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

MAJOR
(SUBR 2)
F - FINAL
NON-CONTAMINATED FLOOR DRAINS
EFFLUENTForm Approved
OMB No. 2040-0004

*** NO DATA ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NC. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE	SAMPLE MEASUREMENT		*****	(07)	*****	*****	*****	*****			
0056 1 0 1	PERMIT REQUIREMENT	REPORT	*****	GPD	*****	*****	*****	****		SEE INSTAN	
EFFLUENT GROSS VALUE		NO AVG						****		PERMIT	
SOLIDS, TOTAL	SAMPLE MEASUREMENT	*****	*****		*****	*****	*****	(19)			
UNSPENDED											
0530 1 0 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.0	MG/L		SEE CHAB	
EFFLUENT GROSS VALUE				****			MAXIMUM			PERMIT	
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
BEON EXTR-GRAV MET											
0556 1 0 1	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20.0	MG/L		SEE CHAB	
EFFLUENT GROSS VALUE				****			INST MAX			PERMIT	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER R.G. CHEVALIER VICE PRESIDENT TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE 203 665-8318		DATE 93 08 02	
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	AREA CODE	NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DETAILED EXPLANATIONS OF ALL PERMIT VIOLATIONS & PROPOSED CORRECTIVE ACTIONS SHALL BE APPENDED.
MONITOR MONTHLY FOR OIL & GREASE WHEN OIL SEPARATOR DISCHARGE OCCURS. IF NO DISCHARGE OCCURS, WRITE "NO"
ON THE TOP RIGHT CORNER OF THE DMR AND LEAVE NON-BLOCKS BLANK.

20-1 (Rev. 9-88) Previous editions may be used.

(REPLACES EPA FORM 7-80 WHICH MAY NOT BE USED.)

00076/930702-1347

PAGE 1 OF

NAME/ADDRESS (Include
Name/Location if different)
UTILITIES (MILLSTONE)
NORTHEAST UTILITIES SERVICE CO
RODE FERRY ROAD
WATERFORD CT 06385
UTILITIES (MILLSTONE)
WATERFORD CT 06141-0270
ATTN: RONALD G. CHEVALIER, VP

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

CT0003263

PERMIT NUMBER

008 1

DISCHARGE NUMBER

MONITORING PERIOD

YEAR MO DAY TO YEAR MO DAY
93 06 01 TO 93 06 30
(120-21) (122-23) (124-25) (126-27) (128-29) (130-31)

MAJOR
(SUBR 2)
F - FINAL


Form Approved
OMB No. 2040-0004

NON-CONTAMINATED FLOOR DRAINS
EFFLUENT

*** NO DATA [] ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-55)	UNITS (56-57)	MINIMUM (58-59)	AVERAGE (60-61)	MAXIMUM (62-63)			
FLOW RATE			*****	(07)	*****	*****				
055 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT NO AVG	*****	GPD	*****	*****	*****	***	SEE INSTAN PERMIT	
OLIDS, TOTAL SPENDED	SAMPLE MEASUREMENT	*****	*****		*****	*****	*****	(19)		
0530 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.0 MAXIMUM	MG/L	SEE GRAB PERMIT	
L AND GREASE	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)		
CEON EXTH-GRAV M&T	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20.0 INST MAX	MG/L	SEE GRAB PERMIT	
0556 1 0 1 EFFLUENT GROSS VALUE										
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER R.G. CHEVALIER VICE PRESIDENT TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE	DATE			
			203 666-5315	93	08	02	
			AREA CODE	NUMBER	YEAR	MO	DAY

MENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ETAILED EXPLANATIONS OF ALL PERMIT VIOLATIONS & PROPOSED CORRECTIVE ACTIONS SHALL BE APPENDED.
MONITOR FOR OIL & GREASE ONLY WHEN OIL SEPARATOR DISCHARGE OCCURS.

NAME W. E. UTILITIES (MILLSTONE)
ADDRESS NORTHEAST UTILITIES SERVICE CO
ROPE FERRY ROAD
WATERFORD CT 06385
FACILITY W. E. UTILITIES (MILLSTONE)
LOCATION WATERFORD CT 06141-0270 FROM
ATTN: RONALD G. CHEVALIER, VP

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

CT0003263

009 1

PERMIT NUMBER

DISCHARGE NUMBER

MAJOR
(SUBR 2)Form Approved
OMB No. 2040-0004

F - FINAL

NON-CONTAMINATED FLOOR DRAINS
EFFLUENT

*** NO DATA ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LOW RATE			*****	(07)	*****	*****					
00556 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT		*****		*****	*****					
	PERMIT REQUIREMENT	REPORT NO AVG	*****	GPD	*****	*****	*****	***		SEE INSTAN PERMIT	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
00530 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.0 MAXIMUM	MG/L		SEE GRAB PERMIT	
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
WHICH EXTR-GRAV MSTR	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20.0 INST MAX	MG/L		SEE GRAB PERMIT	
00556 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$100,000 and/or maximum imprisonment of between 6 months and 5 years.)

R.G. CHEVALIER
VICE PRESIDENT

TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

203 665-5315

AREA
CODE

NUMBER

DATE

93 08 02

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)


DETAILED EXPLANATION OF ALL PERMIT VIOLATIONS AND PROPOSED CORRECTIVE ACTIONS SHALL BE APPENDED.
MONITOR FOR OIL & GREASE WHEN OIL SEPARATOR DISCHARGE OCCURS.

SEE NAME/ADDRESS (Include
County Name/Location if different)
NAME N.E. UTILITIES (MILSTONE)
ADDRESS NORTHEAST UTILITIES SERVICE CO
2025 PERRY ROAD
WATERFORD CT 06185
FACILITY N.E. UTILITIES (MILSTONE)
LOCATION WATERFORD CT 06141-0270 FROM
ATTN: RONALD G. CHEVALIER, VP

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
(2-16) (17-19)
CT0003263 0161
PERMIT NUMBER DISCHARGE NUMBER

MAJOR Form Approved
(SUBR 2) OMB No. 2040-0004
F - FINAL
NONCONTAMINATED FLOOR DRAINS
EFFLUENT
*** NO DATA ***
NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (58-65)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW RATE	SAMPLE MEASUREMENT	*****	*****	(07)	*****	*****	*****	*****			
00056 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT NO AVG	*****	GPD	*****	*****	*****	*****		SEE INSTAN PERMIT	
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		*****	*****	*****	(19)			
00530 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.0 MAXIMUM	MG/L		SEE GRAB PERMIT	
OIL AND GREASE PERSON EXTE-GRAY ACT	SAMPLE MEASUREMENT	*****	*****		*****	*****	*****	(19)			
00556 1 0 1 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	20.0 INST MAX	MG/L		SEE GRAB PERMIT	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER R.G. CHEVALIER VICE PRESIDENT TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$100,000 and/or maximum imprisonment of between 6 months and 5 years.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE		DATE		
			203.665-6316	93	08	02	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DETAILED EXPLANATIONS OF ALL PERMIT VIOLATIONS & PROPOSED CORRECTIVE ACTIONS SHALL BE APPENDED.
MONITOR FOR OIL & GREASE WHEN OIL SEPARATOR DISCHARGE OCCURS.