

AUG 26 1985

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: COMBINED LEAKAGE RATE FOR CONTAINMENT PENETRATIONS AND
ISOLATION VALVES

Re: Oyster Creek Nuclear Generating Station

By letter dated September 25, 1984, GPU Nuclear (the licensee) proposed a change to Section 4.5, Containment, Surveillance Requirements, of the Appendix A Technical Specifications (TS). The change was to revise TS 4.5.F.1.b to accommodate the inclusion of additional isolation valves under the Type C testing requirement of Appendix J to 10 CFR Part 50 and to revise the acceptance criteria for all containment penetrations and isolation valves subject to Type B and Type C testing. Since receipt of the licensee's submittal, the staff has had discussions with the licensee on the proposed TS 4.5.F.1.b and the licensee has decided to submit a new proposed technical specification to the staff in this area.

In the staff's June/July Progress Review meeting with the licensee on July 31 and August 1, 1985, the licensee agreed to withdraw its September 25, 1984, request. This closes out the staff's action this submittal.

A copy of the enclosed Notice of Withdrawal of Application for Amendment is being forwarded to the Federal Register for publication.

Sincerely,

Original signed by

John A. Zwolinski, Chief
Operating Reactors Branch No. 5
Division of Licensing

Enclosure:
Federal Register Notice

cc w/enclosure:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#5 Reading
HThompson

EJordan
BGrimes
JPartlow
JDonohew
CJamerson

OELD
RDiggs w/TACS
ACRS (10)
JZwolinski

DL:ORB#5
JDonohew:tm
08/17/85

DL:ORB#5
CJamerson
08/13/85

OELD
JZwolinski
08/15/85

DL:ORB#5
JZwolinski
08/17/85

8508290030
PDR ADDCK 850826
P 05000219
PDR

SEOL
11 Et(51)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 26, 1985

Docket No. 50-219
LS05-85-08-029

Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: COMBINED LEAKAGE RATE FOR CONTAINMENT PENETRATIONS AND
ISOLATION VALVES

Re: Oyster Creek Nuclear Generating Station

By letter dated September 25, 1984, GPU Nuclear (the licensee) proposed a change to Section 4.5, Containment, Surveillance Requirements, of the Appendix A Technical Specifications (TS). The change was to revise TS 4.5.F.1.b to accommodate the inclusion of additional isolation valves under the Type C testing requirement of Appendix J to 10 CFR Part 50 and to revise the acceptance criteria for all containment penetrations and isolation valves subject to Type B and Type C testing. Since receipt of the licensee's submittal, the staff has had discussions with the licensee on the proposed TS 4.5.F.1.b and the licensee has decided to submit a new proposed technical specification to the staff in this area.

In the staff's June/July Progress Review meeting with the licensee on July 31 and August 1, 1985, the licensee agreed to withdraw its September 25, 1984, request. This closes out the staff's action this submittal.

A copy of the enclosed Notice of Withdrawal of Application for Amendment is being forwarded to the Federal Register for publication.

Sincerely,

A handwritten signature in dark ink, appearing to read "John A. Zwolinski".

John A. Zwolinski, Chief
Operating Reactors Branch No. 5
Division of Licensing

Enclosure:
Federal Register Notice

cc w/enclosure:
See next page

Mr. P. B. Fiedler
Oyster Creek Nuclear Generating Station

Oyster Creek Nuclear
Generating Station

cc:

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Resident Inspector
c/o U.S. NRC
Post Office Box 445
Forked River, New Jersey 08731

J.B. Liberman, Esquire
Bishop, Liberman, Cook, et al.
1155 Avenue of the Americas
New York, New York 10036

Commissioner
New Jersey Department of Energy
101 Commerce Street
Newark, New Jersey 07102

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Eugene Fisher, Assistant Director
Division of Environmental Quality
Department of Environmental
Protection
380 Scotch Road
Trenton, New Jersey 08628

BWR Licensing Manager
GPU Nuclear
100 Interpace Parkway
Parsippany, New Jersey 07054

Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
36 West State Street - CN 112
Trenton, New Jersey 08625

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

D. G. Holland
Licensing Manager
Oyster Creek Nuclear Generating Station
Post Office Box 388
Forked River, New Jersey 08731