

Northeast
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

November 9, 1996

Docket No. 50-423
B15965

Re: 10CFR 50.73(a)(2)(i)


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report 96-038-00, documenting a condition that was determined at Millstone Unit No. 3 on October 10, 1996. This LER is submitted pursuant to 10CFR 50.73(a)(2)(i).

NNECO's commitments in response to this event are contained within Attachment 1 to this letter

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY


M. H. Brothers

Unit Director, Millstone Unit No. 3

Attachment: 1) NNECO's commitments in response to LER 96-038-00
2) LER 96-038-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3

9611140280 961109
PDR ADOCK 05000423
S PDR

1/1
1222

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's commitments
in response

Violation of Technical Specifications Pertaining to High Pressure
Safety Injection & Charging System Pumps
(LER 96-038-00)

November 9, 1996

The following are NNECO's commitments made within this letter:

- B15965-01: A review of the Technical Specifications and implementing procedures to ensure the Limiting Conditions for Operation and Surveillance Requirements can be met for both their intent and for verbatim compliance will be performed. Required Technical Specification change requests will be developed, submitted to the NRC, and approved prior to entry into mode 4.
- B15965-02: A Technical Specification change request will be submitted to the NRC to resolve the conflict between Technical Specifications 3.1.2.4, 3.5.2 and 3.5.3. This change request will be submitted prior to entry into Mode 4.
- B15965-03: The procedures affected by the conflict between Technical Specifications 3.1.2.4, 3.5.2 and 3.5.3 will be changed prior to entry into Mode 4.
- B15965-04: The Unit Director will provide the unit staff with his expectations on compliance with Technical Specifications.