

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

August 21, 1985

Mr. Harold R. Denton, Director
Office of Nuclear Regulation
Attn: Mr. H. L. Thompson, Jr., Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 85-607
NAPS/JHL
Docket No. 50-339
License No. NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NO. 2
CONFIRMATION OF COMPLETION OF LICENSE CONDITION 2.C(18)


North Anna Unit No. 2 license condition 2.C(18) requires that no later than five years from the date of issuance of the license, VEPCO demonstrate to the satisfaction of the Commission that its examination techniques provide a reliable means of detection and evaluation of individual reactor vessel nozzle clad cracks should they grow larger than the acceptance standards contained in ASME Section XI.

VEPCO has performed an inservice inspection of the reactor vessel nozzles. The examination was performed as required by the Technical Specifications, ASME Section XI, 1974 Edition, 1975 Summer Addenda, and Regulatory Guide 1.150, using the Westinghouse remotely operated reactor vessel inservice inspection tool. A description of the inservice inspection that was performed and a summary report of the examination results is included in the attachment (refer to the Reactor Vessel Inservice Inspection Program). The examination results did not indicate any significant degradation. Should you require more detailed information, the entire report is maintained on file at North Anna Power Station and at the corporate office.

VEPCO believes that the completion of the inservice inspection for the reactor vessel nozzles completes the requirements of License Condition 2.C(18).

If you should require further information, please contact us.

Very truly yours,


W. L. Stewart

Attachment

8506290234 850821
PDR ADOCK 05000339
G PDR

A047
11

cc: Dr. J. Nelson Grace
Regional Administrator
Region II

Mr. Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

Mr. M. W. Branch
NRC Resident Inspector
North Anna Power Station

ATTACHMENT TO VEPCO LETTER

SERIAL NO. 85-607