

ATTACHMENT 1

**REVISED PAGES
PROPOSED TECHNICAL SPECIFICATIONS CHANGES
INTERMEDIATE RANGE NEUTRON FLUX TRIP SETPOINTS AND ALLOWABLE
VALUES**

NORTH ANNA POWER STATION UNITS 1 AND 2

TABLE 2.2-1
REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. Manual Reactor Trip	Not Applicable	Not Applicable
2. Power Range, Neutron Flux	Low Setpoint - $\leq 25\%$ of RATED THERMAL POWER High Setpoint - $\leq 109\%^{**}$ of RATED THERMAL POWER	Low Setpoint - $\leq 26\%$ of RATED THERMAL POWER High Setpoint - $\leq 110\%^{***}$ of RATED THERMAL POWER
3. Power Range, Neutron Flux, High Positive Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
4. Power Range, Neutron Flux, High Negative Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
5. Intermediate Range, Neutron Flux	$\leq 35\%$ of RATED THERMAL POWER	$\leq 40\%$ of RATED THERMAL POWER
6. Source Range, Neutron Flux	$\leq 10^5$ counts per second	$\leq 1.3 \times 10^5$ counts per second
7. Overtemperature ΔT	See Note 1	See Note 3
8. Overpower ΔT	See Note 2	See Note 3
9. Pressurizer Pressure - Low	≥ 1870 psig	≥ 1860 psig
10. Pressurizer Pressure - High	≤ 2360 psig	≤ 2370 psig
11. Pressurizer Water Level - High	$\leq 92\%$ of instrument span	$\leq 93\%$ of instrument span
12. Loss of Flow	$\geq 90\%$ of design flow per loop*	$\geq 89\%$ of design flow per loop*

* Design flow per loop is one-third of the minimum allowable Reactor Coolant System Total Flow Rate as specified in Table 3.2-1.

** The high trip setpoint for Power Range, Neutron Flux, shall be $\leq 103\%$ RATED THERMAL POWER for the period of operation until steam generator replacement.

*** The allowable value for the high trip setpoint for Power Range, Neutron Flux, is required to be $\leq 104\%$ RATED THERMAL POWER for the period of operation until steam generator replacement.

LIMITING SAFETY SYSTEM SETTINGS

BASES

The Power Range Negative Rate Trip provides protection for control rod drop accidents. At high power, a rod drop accident could cause local flux peaking which could cause an unconservative local DNBR to exist. The Power Range Negative Rate Trip will prevent this from occurring by tripping the reactor. No credit is taken for operation of the Power Range Negative Rate Trip for those control rod drop accidents for which the DNBR's will be greater than the applicable design limit DNBR value for each fuel type.

Intermediate and Source Range, Nuclear Flux

The Source Range Nuclear Flux trip provides reactor core protection during shutdown (Modes 3, 4 and 5) when the reactor trip system breakers are in the closed position. The Source and Intermediate Range trips in addition to the Power Range trips provide core protection during reactor startup (Mode 2). Reactor startup is prohibited unless the Source, Intermediate and Power Range trips are operable in accordance with Specification 3.3.1.1. The Source Range Channels will initiate a reactor trip at about 10^{+5} counts per second unless manually blocked when P-6 becomes active. The Intermediate Range Channels will initiate a reactor trip at a current level proportional to approximately 35 percent of RATED THERMAL POWER unless manually blocked when P-10 becomes active. In the accident analyses, bounding transient results are based on reactivity excursions from an initially critical condition, where the source range trip is assumed to be blocked. Accidents initiated from a subcritical condition would produce less severe results since the source range trip would provide core protection at a lower power level. No credit was taken for operation of the trip associated with the Intermediate Range Channels in the accident analyses; however, their functional capability at the specified trip settings is required by this specification to enhance the overall reliability of the Reactor Protection System.

Overtemperature ΔT

The Overtemperature ΔT trip provides core protection to prevent DNB for all combinations of pressure, power, coolant temperature, and axial power distribution, provided that the transient is slow with respect to piping transient delays from the core to the temperature detectors (about 4 seconds), and pressure is within the range between the High and Low Pressure reactor trips. This setpoint includes corrections for changes in density and heat capacity of water with temperature and dynamic compensation for piping delays from the core to the loop temperature detectors. With normal axial power distribution, this reactor trip limit is always below the core safety limit as shown in Figure 2.1-1. If axial peaks are greater than design, as indicated by the difference between top and bottom power range nuclear detectors, the reactor trip is automatically reduced according to the notations in Table 2.2-1.

TABLE 3.3-i
REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	1, 2 and *	12
2. Power Range, Neutron Flux	4	2	3	1, 2	2 [#]
3. Power Range, Neutron Flux High Positive Rate	4	2	3	1, 2	2 [#]
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	1, 2	2 [#]
5. Intermediate Range, Neutron Flux	2	1	2	1 ^{###} , 2	3
6. Source Range, Neutron Flux					
A. Startup	2	1	2	2 ^{##}	4
B. Shutdown	2	1	2	3*, 4* and 5*	15
C. Shutdown	2	0	1	3, 4 and 5	5
7. Overtemperature ΔT					
Three Loop Operation	3	2	2	1, 2	7 [#]
Two Loop Operation	3	1 ^{**}	2	1, 2	9

TABLE 3.3-1 (Continued)

TABLE NOTATION

- * With the reactor trip system breakers in the closed position and the control rod drive system capable of rod withdrawal.
- ** The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped condition.
- *** With the Reactor Trip Breaker open for surveillance testing in accordance with Specification Table 4.3-1 (item 21A).
- # The provisions of Specification 3.0.4 are not applicable.
- ## High voltage to detector may be de-energized above the P-6.
- ### Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

ACTION STATEMENTS

- ACTION 1 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, be in HOT STANDBY within 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.1.1.1 provided the other channel is operable.
- ACTION 2 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and POWER OPERATION may proceed provided the following conditions are satisfied:
- The inoperable channel is placed in the tripped condition within 1 hour.
 - The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 2 hours for surveillance testing of the redundant channel(s) per Specification 4.3.1.1.1.
 - Either, THERMAL POWER is restricted to $\leq 75\%$ of RATED THERMAL POWER and the Power Range, Neutron Flux trip setpoint is reduced to $\leq 85\%$ of RATED THERMAL POWER within 4 hours; or, the QUADRANT POWER TILT RATIO is monitored at least once per 12 hours.
 - The QUADRANT POWER TILT RATIO shall be determined to be within the limit when above 75 percent of RATED THERMAL POWER with one Power Range Channel inoperable by using the moveable incore detectors to confirm that the normalized symmetric power distribution, obtained from 2 sets of 4 symmetric thimble locations or a full-core flux map, is consistent with the indicated QUADRANT POWER TILT RATIO at least once per 12 hours.
- ACTION 3 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:

TABLE 3.3-1 (Continued)

	<ul style="list-style-type: none">a. Below P-6, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.b. Above P-6 but below the P-10 setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-10 setpoint.c. Above the P-10 setpoint, POWER OPERATION may continued.
ACTION 4 -	With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement and with the THERMAL POWER level: <ul style="list-style-type: none">a. Below P-6, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.b. Above P-6, operation may continue.
ACTION 5 -	With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, verify compliance with the SHUTDOWN MARGIN requirements of Specification 3.1.1.1 or 3.1.1.2, as applicable, within 1 hour and at least once per 12 hours thereafter.
ACTION 6 -	Not applicable.
ACTION 7 -	With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and POWER OPERATION may proceed until performance of the next required CHANNEL FUNCTIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.
ACTION 8 -	Not applicable.

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	R ⁽⁷⁾	1, 2 and *
2. Power Range, Neutron Flux	S	D ⁽²⁾ , M ⁽³⁾ and Q ⁽⁶⁾	M	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	M	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	M	1, 2
5. Intermediate Range, Neutron Flux	a. S b. M ⁽¹¹⁾	R ^(6, 12) N.A.	M, S/U ⁽¹⁾ N.A.	1***, 2 3*, 4*, 5*
6. Source Range, Neutron Flux	N.A.	R ⁽⁶⁾	M, S/U ⁽¹⁾	2, 3, 4 and 5
7. Overtemperature ΔT	S	R ⁽⁶⁾	M	1, 2
8. Overpower ΔT	S	R ⁽⁶⁾	M	1, 2
9. Pressurizer Pressure – Low	S	R	M	1, 2
10. Pressurizer Pressure – High	S	R	M	1, 2
11. Pressurizer Water Level – High	S	R	M	1, 2
12. Loss of Flow – Single Loop	S	R	M	1

TABLE 4.3-1 (Continued)

NOTATION

- * – With the reactor trip system breakers closed and the control rod drive system capable of rod withdrawal.
- *** – Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.
- (1) – If not performed in previous 7 days.
- (2) – Heat balance only, above 15% of RATED THERMAL POWER.
- (3) – Compare incore to excore axial offset above 15% of RATED THERMAL POWER. Adjust channel if absolute difference ≥ 3 percent.
- (4) – Manual ESF functional input check every 18 months.
- (5) – Each train or logic channel shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (6) – Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (7) – The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the manual reactor trip function. The test shall also verify the operability of the Bypass Breaker Trip circuit(s).
- (8) – Local manual shunt trip prior to placing the bypass breaker into service.
- (9) – Automatic undervoltage trip.
- (10) – The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip attachments on the Reactor Trip Breakers.
- (11) – Monthly Surveillance in Modes 3*, 4* and 5* shall also include verification that Permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window.
- (12) – Detector plateau curves shall be obtained and evaluated. The provisions of Specification 4.0.4 are not applicable for entry into Mode 2 or 1.

SPECIAL TEST EXCEPTIONS

PHYSICS TESTS

LIMITING CONDITION FOR OPERATION

3.10.3 The limitations of Specifications 3.1.1.4, 3.1.3.1, 3.1.3.5 and 3.1.3.6 may be suspended during the performance of PHYSICS TESTS provided:

- a. The THERMAL POWER does not exceed 5% of RATED THERMAL POWER,
- b. The reactor trip setpoints on the OPERABLE Intermediate Range Channels are set at less than or equal to 35% of RATED THERMAL POWER, and
- c. The reactor trip setpoints on the OPERABLE Power Range Channels are set at less than or equal to 25% of RATED THERMAL POWER.

APPLICABILITY: MODE 2.

ACTION:

With the THERMAL POWER > 5% of RATED THERMAL POWER, immediately open the reactor trip breakers.

SURVEILLANCE REQUIREMENTS

4.10.3.1 The THERMAL POWER shall be determined to be $\leq 5\%$ of RATED THERMAL POWER at least once per hour during PHYSICS TESTS.

4.10.3.2 Each Intermediate and Power Range Channel shall be subjected to a CHANNEL FUNCTIONAL TEST within 12 hours prior to initiating PHYSICS TESTS.

SPECIAL TEST EXCEPTIONS

REACTOR COOLANT LOOPS

LIMITING CONDITION FOR OPERATION

3.10.4 The limitations of Specification 3.4.1.1 may be suspended during the performance of startup and PHYSICS TESTS provided:

- a. The THERMAL POWER does not exceed the P-7 Interlock Setpoint,
- b. The Reactor Trip Setpoints on the OPERABLE Intermediate Range Channels are set at less than or equal to 35% of RATED THERMAL POWER, and
- c. The Reactor Trip Setpoints on the OPERABLE Power Range Channels are set at less than or equal to 25% of RATED THERMAL POWER.

APPLICABILITY: During operation below the P-7 Interlock Setpoint.

ACTION:

With the THERMAL POWER greater than the P-7 Interlock Setpoint, immediately open the reactor trip breakers.

SURVEILLANCE REQUIREMENTS

4.10.4.1 The THERMAL POWER shall be determined to be less than P-7 Interlock Setpoint at least once per hour during startup and PHYSICS TESTS.

4.10.4.2 Each Intermediate, Power Range Channel and P-7 Interlock shall be subjected to a CHANNEL FUNCTION TEST within 12 hours prior to initiating startup or PHYSICS TESTS.

TABLE 2.2-1
REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. Manual Reactor Trip	Not Applicable	Not Applicable
2. Power Range, Neutron Flux	Low Setpoint - $\leq 25\%$ of RATED THERMAL POWER High Setpoint - $\leq 109\%$ of RATED THERMAL POWER	Low Setpoint - $\leq 26\%$ of RATED THERMAL POWER High Setpoint - $\leq 110\%$ of RATED THERMAL POWER
3. Power Range, Neutron Flux, High Positive Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
4. Power Range, Neutron Flux, High Negative Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant ≥ 2 seconds
5. Intermediate Range, Neutron Flux	$\leq 35\%$ of RATED THERMAL POWER	$\leq 40\%$ of RATED THERMAL POWER
6. Source Range, Neutron Flux	$\leq 10^5$ counts per second	$\leq 1.3 \times 10^5$ counts per second
7. Overtemperature ΔT	See Note 1	See Note 3
8. Overpower ΔT	See Note 2	See Note 3
9. Pressurizer Pressure - Low	≥ 1870 psig	≥ 1860 psig
10. Pressurizer Pressure - High	≤ 2360 psig	≤ 2370 psig
11. Pressurizer Water Level - High	$\leq 92\%$ of instrument span	$\leq 93\%$ of instrument span
12. Loss of Flow	$\geq 90\%$ of design flow per loop*	$\geq 89\%$ of design flow per loop*

* Design flow per loop is one-third of the minimum allowable Reactor Coolant System Total Flow Rate as specified in Table 3.2-1.

LIMITING SAFETY SYSTEM SETTINGS

BASES

Intermediate and Source Range, Nuclear Flux

The Source Range Nuclear Flux trip provides reactor core protection during shutdown (Modes 3, 4, and 5) when the reactor trip system breakers are in the closed position. The Source and Intermediate Range trips in addition to the Power Range trips provide core protection during reactor startup (Mode 2). Reactor startup is prohibited unless the Source, Intermediate and Power Range trips are operable in accordance with Specification 3.3.1.1. The Source Range Channels will initiate a reactor trip at about 10^{+5} counts per second unless manually blocked when P-6 becomes active. The Intermediate Range Channels will initiate a reactor trip at a current level proportional to approximately 35 percent of RATED THERMAL POWER unless manually blocked when P-10 becomes active. In the accident analyses, bounding transient results are based on reactivity excursions from an initially critical condition, where the source range trip is assumed to be blocked. Accidents initiated from a subcritical condition would produce less severe results since the source range trip would provide core protection at a lower power level. No credit was taken for operation of the trip associated with the Intermediate Range Channels in the accident analyses; however, their functional capability at the specified trip settings is required by this specification to enhance the overall reliability of the Reactor Protection System.

Overtemperature Delta T

The Overtemperature Delta T trip provides core protection to prevent DNB for all combinations of pressure, power, coolant temperature, and axial power distribution, provided that the transient is slow with respect to piping transient delays from the core to the temperature detectors (about 4 seconds), and pressure is within the range between the High and Low Pressure reactor trips. This setpoint includes corrections for changes in density and heat capacity of water with temperature and dynamic compensation for piping delays from the core to the loop temperature detectors. With normal axial power distribution, this reactor trip limit is always below the core safety limit as shown in Figure 2.1-1. If axial peaks are greater than design, as indicated by the difference between top and bottom power range nuclear detectors, the reactor trip is automatically reduced according to the notations in Table 2.2-1.

Operation with a reactor coolant loop out of service below the 3 loop P-8 setpoint does not require reactor protection system setpoint modification because the P-8 setpoint and associated trip will prevent DNB during 2 loop operation exclusive of the Overtemperature Delta T setpoint. Two loop operation above the 3 loop P-8 setpoint is permissible after resetting the K_1 , K_2 and K_3 inputs to the Overtemperature Delta T channels and raising the P-8 setpoint to its 2 loop value. In this mode of operation, the P-8 interlock and trip functions as a High Neutron Flux trip at the reduced power level.

TABLE 3.3-1
REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2	1	2	1, 2 and *	12
2. Power Range, Neutron Flux	4	2	3	1, 2	2 [#]
3. Power Range, Neutron Flux High Positive Rate	4	2	3	1, 2	2 [#]
4. Power Range, Neutron Flux, High Negative Rate	4	2	3	1, 2	2 [#]
5. Intermediate Range, Neutron Flux	2	1	2	1 ^{#, #} , 2	3
6. Source Range, Neutron Flux					
A. Startup	2	1	2	2 ^{##}	4
B. Shutdown	2	1	2	3*, 4* and 5*	15
C. Shutdown	2	0	1	3, 4 and 5	5
3. Overtemperature ΔT					
Three Loop Operation	3	2	2	1, 2	7 [#]
Two Loop Operation	3	1**	2	1, 2	9

TABLE 3.3-1(CONTINUED)

TABLE NOTATION

- * With the reactor trip system breakers in the closed position and the control rod drive system capable of rod withdrawal.
- ** The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped condition.
- *** With the Reactor Trip Breaker open for surveillance testing in accordance with Specification Table 4.3-1 (item 21A).
- # The provisions of Specification 3.0.4 are not applicable.
- ## High voltage to detector may be de-energized above the P-6, (Block of Source Range Reactor Trip), setpoint.
- ### Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

ACTION STATEMENTS

- ACTION 1 – With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirements, be in HOT STANDBY within 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.1.1.1 provided the other channel is OPERABLE.
- ACTION 2 – With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour.
 - b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 2 hours for surveillance testing of the redundant channel(s) per Specification 4.3.1.1.1.
 - c. Either, THERMAL POWER is restricted to $\leq 75\%$ of RATED THERMAL POWER and the Power Range, Neutron Flux trip setpoint is reduced to $\leq 8.5\%$ of RATED THERMAL POWER within 4 hours; or, the QUADRANT POWER TILT RATIO is monitored at least once per 12 hours.
 - d. The QUADRANT POWER TILT RATIO shall be determined to be within the limit when above 75 percent of RATED THERMAL POWER with one Power Range Channel inoperable by using the movable incore detectors to confirm that the normalized symmetric power distribution, obtained from 2 sets of 4 symmetric thimble locations or a full-core flux map, is consistent with the indicated QUADRANT POWER TILT RATIO at least once per 12 hours.

TABLE 3.3-1 (CONTINUED)

- ACTION 3 – With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:
- Below the P-6, (Block of Source Range Reactor Trip) setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.
 - Above the P-6 (Block of Source Range Reactor Trip) setpoint, but below the P-10 setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-10 setpoint.
 - Above the P-10 setpoint, POWER OPERATION may continued.
- ACTION 4 – With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement and with the THERMAL POWER level:
- Below P-6, (Block of Source Range Reactor Trip) setpoint, restore the inoperable channel to OPERABLE status prior to increasing THERMAL POWER above the P-6 Setpoint.
 - Above P-6, (Block of Source Range Reactor Trip) setpoint, operation may continue.
- ACTION 5 – With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, verify compliance with the SHUTDOWN MARGIN requirements of Specification 3.1.1.1 or 3.1.1.2, as applicable, within 1 hour and at least once per 12 hours thereafter.
- ACTION 6 – Not applicable.
- ACTION 7 – With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and POWER OPERATION may proceed until performance of the next required CHANNEL FUNCTIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 8 – Not applicable.

TABLE 4.31

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	R ⁽⁸⁾	1, 2 and *
2. Power Range, Neutron Flux	S	D ⁽²⁾ , M ⁽³⁾ and Q ⁽⁶⁾	M	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R ⁽⁶⁾	M	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R ⁽⁶⁾	M	1, 2
5. Intermediate Range, Neutron Flux	a. S b. M ⁽¹²⁾	R ^(6, 13) N.A.	M, S/U ⁽¹⁾ N.A.	1***, 2 3*, 4*, 5*
6. Source Range, Neutron Flux	S ⁽⁷⁾	R ⁽⁶⁾	M, S/U ⁽¹⁾	2, 3, 4, 5 and *
7. Overtemperature ΔT	S	R ⁽⁶⁾	M	1, 2
8. Overpower ΔT	S	R ⁽⁶⁾	M	1, 2
9. Pressurizer Pressure - Low	S	R	M	1, 2
10. Pressurizer Pressure - High	S	R	M	1, 2
11. Pressurizer Water Level - High	S	R	M	1, 2
12. Loss of Flow - Single Loop	S	R	M	1

TABLE 4.3-1(CONTINUED)

NOTATION

- * – With the reactor trip system breakers closed and the control rod drive system capable of rod withdrawal.
- ** – Surveillance requirements for the manual ESF functional test of the safety injection input to the reactor trip breakers is suspended for the duration of Cycle 9 operation.
- *** – Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.
- (1) – If not performed in previous 7 days.
- (2) – Heat balance only, above 15% of RATED THERMAL POWER. Adjust channel if absolute difference >2 percent.
- (3) – Compare incore to excore axial offset above 15% of RATED THERMAL POWER. Recalibrate if absolute difference \geq 3 percent.
- (4) – Manual ESF functional input check every 18 months.
- (5) – Each train or logic channel shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (6) – Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (7) – Below the P-6, (Block of Source Range Reactor Trip) Setpoint.
- (8) – The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the Manual Reactor Trip Function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit(s).
- (9) – Local manual shunt trip prior to placing the bypass breaker into service.
- (10) – Automatic undervoltage trip.
- (11) – The CHANNEL FUNCTIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip attachments of the Reactor Trip Breakers.
- (12) – Monthly Surveillance in Modes 3*, 4* and 5* shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window.
- (13) – Detector plateau curves shall be obtained and evaluated. The provisions of Specification 4.0.4 are not applicable for entry into Mode 2 or 1.

SPECIAL TEST EXCEPTIONS

PHYSICS TESTS

LIMITING CONDITION FOR OPERATION

3.10.3 The limitations of Specifications 3.1.1.4, 3.1.1.5, 3.1.3.1, 3.1.3.5 and 3.1.3.6 may be suspended during the performance of PHYSICS TESTS provided:

- a. The THERMAL POWER does not exceed 5% of RATED THERMAL POWER,
- b. The reactor trip setpoints on the OPERABLE intermediate Range Channels are set at less than or equal to 35% of RATED THERMAL POWER,
- c. The reactor trip setpoints on the OPERABLE Power Range Channels are set at less than or equal to 25% of RATED THERMAL POWER, and
- d. The Reactor Coolant System lowest operating loop temperature (T_{avg}) is greater than or equal to 531°F.

APPLICABILITY: MODE 2.

ACTION:

- a. With the THERMAL POWER greater than 5% of RATED THERMAL POWER, immediately open the reactor trip breakers.
- b. With a Reactor Coolant System operating loop temperature (T_{avg}) less than 531°F, restore T_{avg} to within its limit within 15 minutes or be in at least HOT STANDBY within the next 15 minutes.

SURVEILLANCE REQUIREMENTS

4.10.3.1 The THERMAL POWER shall be determined to be less than or equal to 5% of RATED THERMAL POWER at least once per hour during PHYSICS TESTS.

4.10.3.2 Each Intermediate and Power Range Channel shall be subjected to a CHANNEL FUNCTIONAL TEST within 12 hours prior to initiating PHYSICS TESTS.

4.10.3.3 The Reactor Coolant System temperature (T_{avg}) shall be determined to be greater than or equal to 531°F at least once per 30 minutes during PHYSICS TESTS.

SPECIAL TEST EXCEPTIONS

REACTOR COOLANT LOOPS

LIMITING CONDITION FOR OPERATION

3.10.4 The limitations of Specification 3.4.1.1 may be suspended during the performance of startup and PHYSICS TESTS provided:

- a. The THERMAL POWER does not exceed the P-7 Interlock Setpoint,
- b. The reactor trip setpoints on the OPERABLE Intermediate Range Channels are set at less than or equal to 35% of RATED THERMAL POWER, and
- c. The reactor trip setpoints on the OPERABLE Power Range Channels are set at less than or equal to 25% of RATED THERMAL POWER.

APPLICABILITY: During operation below the P-7 Interlock Setpoint.

ACTION:

With the THERMAL POWER greater than the P-7 Interlock Setpoint, immediately open the reactor trip breakers.

SURVEILLANCE REQUIREMENTS

4.10.4.1 The THERMAL POWER shall be determined to be less than P-7 Interlock Setpoint at least once per hour during startup and PHYSICS TESTS.

4.10.4.2 Each Intermediate, Power Range Channel and P-7 Interlock shall be subjected to a CHANNEL FUNCTIONAL TEST within 12 hours prior to initiating startup or PHYSICS TESTS.