



Northeast
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

November 1, 1996

Docket No. 50-245

50-336

50-423

B15977

S

Re: 10CFR50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 96-053-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on October 2, 1996. This event is reportable for all three Millstone units and this LER is submitted pursuant to 10CFR50.73(a)(2)(i).

The following is Northeast Nuclear Energy Company's (NNECO's) commitment made within this letter. All other statements made within this letter are for information only.

- B15977-1 NNECO will develop necessary procedures to perform monthly source checks for these monitors or properly document an appropriate alternative method of satisfying the surveillance requirement prior to April 1, 1997. The instrument calibrations will be performed monthly to satisfy Technical Specification source check requirements until adequate procedures for source checks are developed.
- B15977-2 NNECO will review the applicability of this event at the other Millstone units to ensure that Technical Specification source check requirements are properly met by December 10, 1996.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp
Director, Unit Operations

Attachment: LER 96-053-00

9611180108 961101
PDR ADOCK 05000245
S PDR

083422-9 REV. 1-95

050038

TEL. 1

cc: H. J. Miller, Region I Administrator
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1
J. W. Andersen, NRC Project Manager, Millstone Unit No. 1
D. P. Beaulieu, Resident Inspector, Millstone Unit No. 2
D. G. McDonald, Jr., NRC Project Manager, Millstone Unit No. 2
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3