



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

Docket No. 50-245  
B16164

Re: 10CFR50.73(a)(2)(i)  
February 10, 1997

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


This letter forwards Licensee Event Report (LER) 97-001-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on January 10, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(i).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16164-1 NNECO commits to identify by April 15, 1997, critical radwaste components and implement a preventative maintenance program to assure operability of these components. The system design basis will be revised to identify these critical components and specify their design requirements by August 22, 1997.
- B16164-2 NNECO commits to conduct a review of the present Liquid Radwaste Discharge system lineup to determine the appropriate configuration and modify the discharge procedures and system configuration as required to ensure the system is operated within the design basis of the plant by March 31, 1997.
- B16164-3 NNECO commits to review Technical Specifications for occurrences where actuated equipment has only implied functional requirements due to association with systems (such as actuating instrumentation) in other sections of Technical Specifications or the Updated Final Safety Analysis Report and specify the functional requirements for these components by April 30, 1998.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
P. D. Hinnenkamp  
Director, Unit Operations

9702120386 970210  
PDR ADOCK 05000245  
S PUR

U.S. Nuclear Regulatory Commission  
B16164\Page 2 of 2

Attachment: LER 97-001-00

cc: Dr. W. D. Travers, Director, Special Projects  
H. J. Miller, Region I Administrator  
S. Dembek, NRC Project Manager, Millstone Unit No. 1  
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1