

STONE & WEBSTER ENGINEERING CORPORATION
QUALITY ASSURANCE DEPARTMENT

NOTES OF TELEPHONE CONVERSATION

T-1928

CALL DATE 6/17/85 TIME 2:15 P.M.
PROJECT Comanche Peak J.O. 15297.00

FROM:

TO:

H.F. Faery NAME R.M. Grant
Asst. Chief Engineer, NDT Division TITLE Director, QA, Kansas Gas & Electric
SWEC Boston ADDRESS Wolf Creek Generating Station
(617) 589-5185 TELEPHONE (316) 364-8831 X2230

SUBJECT Re-inspection of Structural Welds in Power Block - Reference CAR 19

SUMMARY Inspection of welds was carried out through the coating. Welds had
previously been inspected and accepted, but some records were misplaced, thus
requiring a reinspection. NRC did sample inspections to check our results, even
used MT on 59 joints through the paint, then had the paint removed for verification.
No defects were found.

ACTION REQUIRED _____

COPY TO: _____

SIGNATURE *H.F. Faery*