

August 19, 1985

Docket No. 50-285

Mr. R. L. Andrews
Division Manager - Nuclear Production
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Andrews:

DISTRIBUTION:

Docket File

NRC PDR
L PDR
ORB#3 Rdg
HThompson
PMKreutzer-3
ETourigny
OELD
SECY
EJordan

LTremper
RDiggs
OPA, CMiles
ACRS-10
MVirgilio
WJones
TBarnhart-4
BGrimes
LHarmon
Gray File +4

The Commission has issued the enclosed Amendment No. 90 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated June 11, 1985.

The amendment changes the testing frequency of the auxiliary feedwater pumps from quarterly to monthly.

A copy of the Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

/S/

E. G. Tourigny, Project Manager
Operating Reactors Branch #3
Division of Licensing

Enclosures:

1. Amendment No.90 to DPR-40
2. Safety Evaluation

cc w/enclosures:
See next page

ORB#3:DL
PMKreutzer
7/1/85

ORB#3:DL
ETourigny
7/23/85

ORB#3:DL
EButcher
7/31/85

ODP
ASB:DSI
OParr
7/24/85

OELD
M. Lauman
7/24/85

AD:OR:DL
GCLainas
7/31/85

8508300338 850819
PDR ADOCK 05000285
P PDR

Mr. R. L. Andrews
Omaha Public Power District

Ft. Calhoun Station, Unit No. 1

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, DC 20036

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68023

Metropolitan Planning Agency
ATTN: Dagnia Prieditis
7000 West Center Road
Omaha, Nebraska 68107

Mr. Larry Yandell
U.S. NRC Resident Inspector
Post Office Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Bethesda, Maryland 20814

Regional Administrator
USNRC, Region IV
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011