



PECO NUCLEAR

A Unit of PECO Energy

Robert W. Boyce
Plant Manager
Limerick Generating Station

PECO Energy Company
Limerick Generating Station
PO Box 2300
Sanatoga, PA 19464-0920
610 718 2000

November 11, 1996
Docket Nos. 50-352
50-353
License Nos. NPF-39
NPF-85

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Licensee Event Report
Limerick Generating Station - Units 1 and 2

This LER reports operation prohibited by the Technical Specifications in that certain previously established surveillance testing for the Emergency Diesel Generators did not fully verify the capability to reject the specified electrical load of a Residual Heat Removal pump motor due to an inadequate procedure.

Reference:	Docket Nos. 50-352 50-353
Report Number:	1-96-019
Revision Number:	00
Event Date:	October 26, 1984 June 22, 1989
Discovery Date:	October 10, 1996
Report Date:	November 11, 1996
Facility:	Limerick Generating Station PO Box 2300, Sanatoga, PA 19464-2300

This report is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(i)(B) and 10CFR50.73(a)(2)(vii).

Very truly yours,

DBN/cah

cc: H. J. Miller, Administrator Region I, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS

IE22 1/1

9611200302 961111
PDR ADOCK 05000352
S PDR