



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, P.O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RJR 85-395

August 19, 1985

REGION V 12F


1985 AUG 20 AM 10 54

RECEIVED
MRC

J B MARTIN - REGIONAL ADMINISTRATOR
REGION V OFFICE OF INSPECTION AND ENFORCEMENT
U S NUCLEAR REGULATORY COMMISSION
1450 MARIA LANE
SUITE 210
WALNUT CREEK CA 94596

Attached is the information requested by John Stolz in his March 11, 1983, letter to J. J. Mattimoe concerning National Pollutant Discharge Elimination System (NPDES) permit.


Further questions may be directed to Mr. George Campbell, who can be reached at (209) 333-2035, extension 4144.


R. J. RODRIGUEZ
ASSISTANT GENERAL MANAGER,
NUCLEAR

Attachment

8509030360 850819
PDR ADDCK 05000312
R PDR

IE-01



SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

RPO 85-678

August 5, 1985

W H CROOKS
CALIFORNIA WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION
3201 S STREET
SACRAMENTO CA 95814

ORDER 79-03 WATER DISCHARGE REQUIREMENTS
SACRAMENTO MUNICIPAL UTILITY DISTRICT
RANCHO SECO NUCLEAR GENERATING STATION UNIT 1

In accordance with the monitoring and reporting requirements of the subject order, please find attached a summary of the Water Quality Monitoring Program at the Rancho Seco facility for July, 1985.

Additional comments are as follows:

1. Rancho Seco was shut down for refueling, maintenance, inspections, and modifications during the month of July.
2. Maximum waste water flow rate was 10,000 gpm for 8 hours on July 31.
3. Waste water discharges amounted to 159.9 M gallons.
4. Maximum dissolved solids in waste water discharge was 7,749 lbs. per day which occurred during a retention basin release on July 30.
5. Flow through the sewage plant averaged 12,347 gpd for the month of July, which is an overload of plant design.
6. High suspended solids and settleable matter in sewage plant effluent is attributed to flow in excess of design.

R. P. Oubré
Manager, Nuclear Operations
Rancho Seco Nuclear Generating Station
14440 Twin Cities Road, M.S. 200
Herald CA 95638

Attachment

cc: R. J. Rodriguez
L. Keilman

RPO:lgd



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

RPO 85-677

August 5, 1985

REGIONAL ADMINISTRATOR
ENVIRONMENTAL PROTECTION AGENCY
REGION IX
215 FREMONT STREET
SAN FRANCISCO CA 94105

In accordance with reporting requirements of the California Water Quality Control Board, please find enclosed a copy of the report of waste water quality monitoring at Rancho Seco for the month of July, 1985.

R. P. Oubré
Manager, Nuclear Operations
Rancho Seco Nuclear Generating Station
14440 Twin Cities Road, M.S. 200
Herald CA 95638

Enclosure

cc: R. J. Rodriguez
L. Keilman
NRC

RPO:lgd