

February 12, 1997

2CAN029703

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555


Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
1996 Annual Primary Coolant Activity Report

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.e requires an annual submittal of the results of the specific activity analysis in which the primary coolant exceeded the limits of Specification 3.4.8. The specific activity of the primary coolant, as required by Specification 3.4.8, shall be limited to: a) less than or equal to 1.0 microcurie per gram DOSE EQUIVALENT I-131, and b) less than or equal to $100/\bar{E}$ microcuries per gram (where \bar{E} = average disintegration energy). The purpose of this letter is to provide this information for 1996.

During 1996, no samples taken of the primary coolant exceeded the limits of Technical Specification 3.4.8. Should you have any questions regarding this submittal, please contact me.

Very truly yours,



Dwight C. Mims
Director, Nuclear Safety

DCM/jjd

190087

ADD 1/0

9702200136 970212
PDR ADOCK 05000368
R PDR

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. George Kaiman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852