



**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

February 13, 1997

Docket No. 50-245
B16165

Re: 10CFR50.73(a)(2)(iv)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-002-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on January 14, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(iv).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16165-1 NNECO commits that the immediate corrective action, to require two separate reviews of the clearance (tagout) procedure prior to release, will be permanently incorporated through a revision to the clearance (tagout) procedure and process prior to startup for operating Cycle 16.
- B16165-2 NNECO commits to provide additional training in electrical schematic print reading to the licensed personnel prior to startup for operating Cycle 16.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp
Director, Unit Operations

9702200142 970213
PDR ADOCK 05000245
S PDR

Attachment: LER 97-002-00

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

190020

IF22/1