

**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

February 11, 1997

Docket No. 50-443

NYN-97014


United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Seabrook Station
January, 1997 Monthly Operating Report

Enclosed please find Monthly Operating Report 97-01. This report addresses the operating and shutdown experience relating to Seabrook Station Unit 1 for the month of January, 1997 and is submitted in accordance with the requirements of Seabrook Station Technical Specification 6.8.1.5.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.



William A. DiProfi
Station Director

cc: H.J. Miller, Region I Administrator
A.W. De Agazio, NRC Project Manager, Seabrook Station
J.B. Macdonald, Senior Resident Inspector, Seabrook Station

9702200147 970131
PDR ADOCK 05000443
R PDR

190119

JK24/1

OPERATING DATA REPORT

DOCKET NO. 50-443

UNIT Seabrook 1

DATE February 4, 1997

COMPLETED BY P.E. Nardone

TELEPHONE (603) 773-7074

OPERATING STATUS

1.	Unit Name:	Seabrook Station Unit 1		
2.	Reporting Period:	JANUARY, 1997		
3.	Licensed Thermal Power (MWt):	3411		
4.	Nameplate Rating (Gross MWe):	1197		
5.	Design Electrical Rating (Net MWe):	1148		
6.	Maximum Dependable Capacity (Gross MWe):	1204		
7.	Maximum Dependable Capacity (Net MWe):	1158		
8.	If Changes Occur in Capacity Ratings (Items Number 3 through 7) Since Last Report, Give Reasons:	Not Applicable		
9.	Power Level To Which Restricted, If Any (Net MWe):	None		
10.	Reasons For Restrictions, If Any:	Not Applicable		
		This Month	Yr-to-Date	Cumulative
11.	Hours in Reporting Period	744.0	744.0	90241.0
12.	Number of Hours Reactor Was Critical	744.0	744.0	50418.9
13.	Reactor Reserve Shutdown Hours	0.0	0.0	953.3
14.	Hours Generator On-Line	744.0	744.0	48044.8
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	2538753	2538753	158609963
17.	Gross Elec. Energy Generated (MWH)	898351	898351	55280318
18.	Net Electrical Energy Generated (MWH)	864316	864316	55116265
*19.	Unit Service Factor	100.0	100.0	82.5
*20.	Unit Availability Factor	100.0	100.0	82.5
*21.	Unit Capacity Factor (Using MDC Net)	100.3	100.3	79.9
*22.	Unit Capacity Factor (Using DER Net)	101.2	101.2	80.2
*23.	Unit Forced Outage Rate	0.0	0.0	5.4
24.	Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	Refueling, 05/10/97, 38 Days		
25.	If Shut Down At End Of Report Period, Estimated Date of Startup:	Not Applicable		

*NOTE: "Cumulative" values based on total hours starting 8/19/90, date Regular Full Power Operation began.
Increased MDC values (Items 6 & 7) starting 12/01/95.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-443

UNIT Seabrook 1

DATE February 4, 1997

COMPLETED BY P.E. Nardone

TELEPHONE (603) 773-7074

MONTH: JANUARY, 1997

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1161
2	1162
3	1162
4	1163
5	1163
6	1162
7	1162
8	1161
9	1162
10	1162
11	1162
12	1162
13	1162
14	1162
15	1162
16	1163

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	1161
18	1162
19	1161
20	1161
21	1161
22	1162
23	1162
24	1161
25	1162
26	1162
27	1161
28	1162
29	1161
30	1161
31	1161

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-443
UNIT Seabrook 1
DATE February 4, 1997
COMPLETED BY P.E. Nardone
TELEPHONE (603) 773-7074

REPORT MONTH JANUARY 1997

NO.	DATE	TYPE ¹	DURATION (HOURS)	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT #	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE Page 1 of 1
							no entries for this month
¹ F: Forced S: Scheduled		² Reason: A - Equipment Failure (Explain) B - Maintenance or Test C - Refueling D - Regulatory Restriction E - Operator Training & License Examination F - Administrative G - Operational Error (Explain) H - Other (Explain)			³ Method: 1 - Manual 2 - Manual Scram 3 - Automatic Scram 4 - Continued from previous month 5 - Power Reduction (Duration = 0) 9 - Other (Explain)		

REFUELING INFORMATION REQUEST

DOCKET NO.	50-443
UNIT	Seabrook 1
DATE	February 4, 1997
COMPLETED BY	P.E. Nardone
TELEPHONE	(603) 773-7074

1. Name of Facility: Seabrook Unit 1
2. Scheduled date for next refueling shutdown: Refueling Outage 5, 05/10/97
3. Scheduled date for restart following refueling: Refueling Outage 5, 06/16/97 [38 days: based on RO 04]
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
N/A
5. Schedule date(s) for submitting licensing action and supporting information:
N/A
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
N/A
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
(a) In Core: 193 (b) 288
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present licensed capacity: 1236
No increase in storage capacity requested or planned.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:
Licensed capacity of 1236 fuel assemblies based on two annual and twelve eighteen-month refuelings with full core offload capability.
The current licensed capacity is adequate until at least the year 2010.