



Douglas R. Gipson,
Senior Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5249

10CFR50.73

November 14, 1996
NRC-96-0098

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Reference: Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 96-015

Pursuant to 10CFR50.73, Detroit Edison is submitting the enclosed LER No. 96-015 documenting an Engineered Safety Features (ESF) actuation of the Division 2 Emergency Equipment Cooling Water System which occurred during a fill and vent evolution of the portion of this system located in the drywell.

The following commitments are made in this LER:

1. This event will be discussed in Training Cycle 97-01 for licensed and non-licensed operators. The training will emphasize the need for proper pre-evolution briefings, logging requirements for expected ESF actuations, and management expectations.
2. The involved Nuclear Shift Supervisor (NSS) will discuss the lessons learned from this event with all on-shift NSSs by November 30, 1996.
3. An Operations evolution guide will be developed by December 31, 1996. This guide will assist in ensuring that personnel involved in a particular evolution are coordinated and aware of the proper sequence of events.

9611250168 961114
PDR ADOCK 05000741
S DR

IE22/1


November 14, 1996

NRC-96-0098

Page 2

If you have any questions, please contact Andrew V. Antrassian, Compliance Engineer, at (313) 586-1856.

Sincerely,



cc: A. B. Beach
M. J. Jordan
A. J. Kugler
A. Vogel
M. V. Yudas, Jr.
Region III
Wayne County Emergency
Management Division