



CONNECTICUT YANKEE ATOMIC POWER COMPANY

HADDAM NECK PLANT

362 INJUN HOLLOW ROAD • EAST HAMPTON, CT 06424-3099

February 11, 1997

Docket No. 50-213

B16220

Re: NUREG 0737,
Action Item I.C.6

Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555

Haddam Neck Plant

Change of Commitment For NUREG 0737 TMI Action Item I.C.6

The purpose of this letter is for the Connecticut Yankee Atomic Power Company (CYAPCO), to revise the commitment for the Haddam Neck Plant (HNP) to NUREG 0737, TMI Action Items, Action Item I.C.6.

In a letter dated April 1, 1982¹, CYAPCO made the commitment that the job supervisor, instead of a second operator, would verify correct implementation of equipment control measures such as tagging of equipment. In a letter dated January 25, 1984² the NRC accepted CYAPCO's response to TMI Action Item I.C.6.

CYAPCO has decided to revise this commitment to require qualified operators to verify tags. Qualified operators at the HNP including Senior Reactor Operators (SRO), Reactor Operators (RO), Nuclear System Operators (NSO) and, during decommissioning, Certified Fuel Handlers (CFH). These operators possess a knowledge of the systems involved and the relationship of these systems to plant safety. This revised commitment meets the original intent of TMI Action Item I.C.6.

The following is a commitment changed within this letter. Other statements made within this letter are provided as information only.

¹ W. G. Council letter to D. M Crutchfield, "Haddam Neck Plant, Millstone Nuclear Power Station Unit Nos. 1 and 2, NUREG-0737 Items I.A.1.3, I.C.5, and I.C.6," dated April 1, 1982.

² R. W. Starostecki to W. G. Council, "Inspection Report No. 50-213/83-27" dated January 25, 1984.


A0031/0

B16220-1 CYAPCO's commitment to TMI Action Plan Item I.C.6 for the Haddam Neck Plant is modified to state that qualified operators will be used to verify tagging of equipment.

If you have any questions regarding information contained herein, please contact Mr. G. P. van Noordennen at (860)267-3938.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY



T. C. Feigenbaum
Executive Vice President
Chief Nuclear Officer

cc: H. J. Miller, Region I Administrator
M. B. Fairtile, NRC Senior Project Manager, Haddam Neck Plant
W. J. Raymond, Senior Resident Inspector, Haddam Neck Plant
K. T. A. McCarthy, Director, CT DEP Monitoring and Radiation Division