



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

FEB 14 1997

LR-N970116

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354  
UNIT NO. 1  
LICENSEE EVENT REPORT NO. 97-002-00

Dear Sir:

This Licensee Event Report entitled "Inconsistency Between Filtration, Recirculation, and Ventilation System Technical Specifications and the Ability to Withstand Prescribed Single Failures Under Design Basis Conditions" is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(ii)(B).

Sincerely,

Mark Bezilla  
General Manager,  
Hope Creek Operations

JWK/mrh  
SORC Mtg. 97-0105

210008

C Distribution  
LER File

9702210118 970214  
PDR ADOCK 05000354  
S PDR

The power is in your hands.

JE2211

Document Control Desk  
LR-N970116

Attachment A

The following items represent the commitments that the Public Service Electric and Gas Company is making to the Nuclear Regulatory Commission relative to LER 354/97-002-00:

1. The administrative controls to assure a 7 day LCO is entered with one of the six FRVS recirculation units inoperable will remain in place until a TS Amendment can be implemented.
2. A TS amendment to include the sixth unit will be submitted to the NRC by April 30, 1997.