

August 27, 1985

Docket No. 50-344

Mr. Bart D. Withers
Vice President Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Withers:

SUBJECT: GENERIC LETTER 83-28 ITEMS 4.2.1 AND 4.2.2 SAFETY EVALUATION

The staff has completed its review of your response to Generic Letter 83-28, items 4.2.1 and 4.2.2, Preventative Maintenance Program for Reactor Trip Breakers/Maintenance and Trending. The staff's safety evaluation (SE) is enclosed.

The staff finds that PGE's revised preventative maintenance program for reactor trip breakers contains all the necessary items recommended for maintenance by the manufacturer and the IEEE Standard 279-1971. PGE has also committed to performing the appropriate trend analysis. Based on our review, the staff concludes that PGE's positions on items 4.2.1 and 4.2.2 are acceptable.

The NRC staff was assisted in its evaluation of these issues by Idaho National Engineering Laboratory under contract to the NRC.

Sincerely,

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Distribution:

Docket File

NRC & L PDRs

Branch Files

EJordan

HThompson

OELD

PKreutzer

EButcher

BGrimes

LLazo

NRomney

ACRS 10

ORB#3:DL

PKreutzer

8/15/85

ORB#3:DL

LLazo;ef

8/15/85

DE

NRomney

8/26/85

ORB#3:DL

EButcher

8/27/85

Mr. Bart D. Withers
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

William T. Dixon
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
Office of Executive Director for Operations
1450 Maria Lane, Suite 210
Walnut Creek, California 94596