

Docket No. 50-458

AUG 28 1985

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: INFORMATION RELATING TO THE DEADLINES FOR COMPLIANCE WITH 10CFR 50.49,
"ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT TO
SAFETY FOR NUCLEAR POWER PLANTS" (GENERIC LETTER 85-15)

The enclosed Generic Letter 85-15 on Information Relating to the Deadlines for Compliance with 10CFR 50.49 was sent to all licensees of operating reactors on August 6, 1985. As River Bend is expected to receive an operating license shortly, the guidance in this letter is expected to apply to River Bend as well. Generic Letter 85-15 is therefore being provided for your information. In particular, please note that any requests for extension for compliance with 10CFR 50.49 beyond November 30, 1985, that are received after September 30, 1985, will be considered untimely and may be denied on that basis.

There are a number of components at River Bend for which additional environmental qualification is required prior to November 30, 1985, in order for River Bend to be in compliance with 10CFR 50.49. Attention should be given to qualifying this equipment prior to the November 30, 1985 deadline.

Any concerns relating to the above information should be directed to the Licensing Project Manager, Stephen Stern (301) 492-8349.

Sincerely,

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

DISTRIBUTION

Docket File NRC PDR Local PDR PRCSysstem NSIC LB#2Reading IHylton
MHaughey JPartlow BGrimes EJordan OELD,Dewey ACRS(16) HWalker
RLaGrange

LB#2/DL/PM
SStern
8/17/85

W for
LB#2/DL/PM
MHaughey:mk
8/27/85

LB#2/DL/BC
WButler
8/27/85

WB

8509040394 850828
PDR ADOCK 05000458
A PDR

Docket No. 50-458

AUG 28 1985

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: INFORMATION RELATING TO THE DEADLINES FOR COMPLIANCE WITH 10CFR 50.49,
"ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT TO
SAFETY FOR NUCLEAR POWER PLANTS" (GENERIC LETTER 85-15)

The enclosed Generic Letter 85-15 on Information Relating to the Deadlines for Compliance with 10CFR 50.49 was sent to all licensees of operating reactors on August 6, 1985. As River Bend is expected to receive an operating license shortly, the guidance in this letter is expected to apply to River Bend as well. Generic Letter 85-15 is therefore being provided for your information. In particular, please note that any requests for extension for compliance with 10CFR 50.49 beyond November 30, 1985, that are received after September 30, 1985, will be considered untimely and may be denied on that basis.

There are a number of components at River Bend for which additional environmental qualification is required prior to November 30, 1985, in order for River Bend to be in compliance with 10CFR 50.49. Attention should be given to qualifying this equipment prior to the November 30, 1985 deadline.

Any concerns relating to the above information should be directed to the Licensing Project Manager, Stephen Stern (301) 492-8349.

Sincerely,

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

DISTRIBUTION

Docket File NRC PDR Local PDR PRCSysm NSIC LB#2Reading IHylton
MHaughy JPartlow BGrimes EJordan OELD,Dewey ACRS(16) HWalker
RLaGrange

LB#2/DL/PM
Stern
8/27/85

W for
LB#2/DL/PM
MHaughy:mk
8/27/85

LB#2/DL/BC
WButler
8/27/85

WB



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket No. 50-458

AUG 28 1985

Mr. William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
Gulf States Utilities Company
P.O. Box 2951
Beaumont, Texas 77704
Attention Mr. J. E. Booker

Dear Mr. Cahill:

SUBJECT: INFORMATION RELATING TO THE DEADLINES FOR COMPLIANCE WITH 10CFR 50.49,
"ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT TO
SAFETY FOR NUCLEAR POWER PLANTS" (GENERIC LETTER 85-15)

The enclosed Generic Letter 85-15 on Information Relating to the Deadlines for Compliance with 10CFR 50.49 was sent to all licensees of operating reactors on August 6, 1985. As River Bend is expected to receive an operating license shortly, the guidance in this letter is expected to apply to River Bend as well. Generic Letter 85-15 is therefore being provided for your information. In particular, please note that any requests for extension for compliance with 10CFR 50.49 beyond November 30, 1985, that are received after September 30, 1985, will be considered untimely and may be denied on that basis.

There are a number of components at River Bend for which additional environmental qualification is required prior to November 30, 1985, in order for River Bend to be in compliance with 10CFR 50.49. Attention should be given to qualifying this equipment prior to the November 30, 1985 deadline.

Any concerns relating to the above information should be directed to the Licensing Project Manager, Stephen Stern (301) 492-8349.

Sincerely,

A handwritten signature in cursive script, reading "Walter R. Butler".

Walter R. Butler, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure: As stated

cc: See next page

Mr. William J. Cahill, Jr.
Gulf States Utilities Company

River Bend Nuclear Plant

cc:

Troy B. Conner, Jr., Esq.
Conner and Wetterhahn
1747 Pennsylvania Avenue, NW
Washington, D.C. 20006

Ms. Linda B. Watkins/Mr. Steven Irving
Attorney at Law
355 Napoleon Street
Baton Rouge, Louisiana 70802

Mr. William J. Reed, Jr.
Director - Nuclear Licensing
Gulf States Utilities Company
P. O. Box 2951
Beaumont, Texas 77704

Mr. David Zaloudek
Nuclear Energy Division
Louisiana Department of
Environmental Quality
P. O. Box 14690
Baton Rouge, Louisiana 70898

Richard M. Troy, Jr., Esq.
Assistant Attorney General in Charge
State of Louisiana Department of Justice
234 Loyola Avenue
New Orleans, Louisiana 70112

Mr. J. David McNeill, III
William G. Davis, Esq.
Department of Justice
Attorney General's Office
7434 Perkins Road
Baton Rouge, Louisiana 70808

Resident Inspector
P. O. Box 1051
St. Francisville, Louisiana 70775

H. Anne Plettinger
3456 Villa Rose Drive
Baton Rouge, Louisiana 70806

Gretchen R. Rothschild
Louisianians for Safe Energy, Inc.
1659 Glenmore Avenue
Baton Rouge, Louisiana 70775

James W. Pierce, Jr., Esq.
P. O. Box 23571
Baton Rouge, Louisiana 70893

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 6 1985

TO ALL LICENSEES OF OPERATING REACTORS

Gentlemen:

SUBJECT: INFORMATION RELATING TO THE DEADLINES FOR COMPLIANCE
WITH 10 CFR 50.49, "ENVIRONMENTAL QUALIFICATION OF
ELECTRIC EQUIPMENT IMPORTANT TO SAFETY FOR NUCLEAR
POWER PLANTS" (GENERIC LETTER 85-15)

The deadline for compliance with 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants" is specified in the rule as the date of the second refueling outage after March 31, 1982 or March 31, 1985, whichever was earlier. Some plants have received extensions to these deadlines up to November 30, 1985. Where current extensions terminate prior to November 30, 1985, the delegation in 10 CFR 50.49(g) permits the Director of NRR to act on further requests for extensions as long as the new deadline is not beyond November 30, 1985. Section 50.49(g) states that "in exceptional cases, the Commission itself may consider and grant extensions beyond November 30, 1985, for completion of environmental qualification." The purpose of this letter is to advise licensees that it is the Commission's intention that extensions will be granted only in rare circumstances and that enforcement action will be taken against ^{1/}licensees that continue to operate their plants with unqualified equipment ^{2/}beyond November 30, 1985, without extensions approved by the Commission.

It is the Commission's intention that licensees which are not in compliance on November 30, 1985, and which have not been given extensions either will have to either shut down or, if they have valid staff-approved justifications for continued operation, select to operate and face civil penalties of \$5,000 per item ^{2/}per day for each day after November 30, 1985, on which a licensee operates in noncompliance with the rule. For noncompliance identified after November 30, 1985, such fines may be made retroactive to November 30, 1985 for each day a licensee clearly knew, or should have known, that equipment qualification was incomplete. Some mitigation of any penalty may be considered based upon satisfaction of the following factors:

- 1/ For purposes of enforcement, "unqualified equipment" means equipment for which there is not adequate documentation to establish that this equipment will perform its intended functions in the relevant environment.
- 2/ An item is defined as a specific type of electrical equipment, designated by manufacturer and model, which is representative of all identical equipment in a plant area exposed to the same environmental service conditions.


85080701-78 TAP.

1. Did the licensee identify and promptly report the noncompliance with 10 CFR 50.49?
2. Did the licensee apply best efforts to complete environmental qualification within the deadline?
3. Has the licensee proposed actions which can be expected to result in full compliance within a reasonable time?

For equipment which is discovered (through new test results, NRC inspection, or other means) after November 30, 1985, to be in noncompliance or is suspected to be in noncompliance with the requirements of 10 CFR 50.49, licensees should report the finding if the condition found meets the reporting criteria of 10 CFR 50.72 (Prompt Notification) or 10 CFR 50.73 (Licensee Event Reporting System). Evaluations of the significance of and corrective action for all actual and potential noncompliances should be documented as should the circumstances of discovery of the noncompliance or suspected noncompliance. These documents should be retained in appropriate licensee files. If equipment addressed in the plant Technical Specifications is found to be unable to perform its intended function during an accident because of equipment qualification problems, the licensee is required to follow the provisions of the Technical Specifications. A case by case determination will be made whether retroactive enforcement is appropriate for noncompliance identified after November 30, 1985.

Licensees desiring an extension beyond November 30, 1985, must submit an extension request at the earliest possible date to the Commission with a copy to the Director, NRR and the Director, IE. Requests received after September 30, 1985, will be considered untimely, and may be denied on that basis. The basis for any extension request beyond November 30, 1985 must clearly identify the exceptional nature of the case, e.g., why, through events entirely beyond its control, the licensee will not be in compliance with the rule on November 30; the date when compliance will be achieved; and a justification for continued operation until compliance will be achieved.

This letter does not require any response and therefore does not need approval of the Office of Management and Budget. Comments on burden and duplication may be directed to the Office of Management and Budget, Reports Management Room 3208, New Executive Office Building, Washington, D.C. 20503. Should you have any questions, the staff contacts are Gary Holahan for technical questions and Jane Axelrad for enforcement questions. Mr. Holahan can be reached on (301)492-7415 and Ms. Axelrad can be reached on (301)492-4909.


Hugh L. Thompson, Jr., Director
Division of Licensing

cc: List of Generic Letters

LIST OF RECENTLY ISSUED GENERIC LETTERS

<u>GENERIC LETTER NO.</u>	<u>SUBJECT</u>	<u>DATE</u>
85-01	Fire Protection Policy Steering Committee Report	1/9/85
85-02	Staff Recommended Actions Stemming From NRC Integrated Program for the Resolution of Unresolved Safety Issues Regarding Steam Generator Tube Integrity	4/15/85
85-03	Clarification of Equivalent Control Capacity For Standby Liquid Control Systems	1/28/85
85-04	Operator Licensing Examinations	1/29/85
85-05	Inadvertent Boron Dilution Events	1/31/85
85-06	Quality Assurance Guidance for ATWS Equipment that is not Safety-Related	4/16/85
85-07	Implementation of Integrated Schedules for Plant Modifications	5/02/85
85-08	10 CFR 20.408 Termination Reports - Format	5/23/85
85-09	Technical Specifications for Generic Letter 83-28, Item 4.3	5/23/85
85-10	Technical Specifications for Generic Letter 83-28, Items 4.3 and 4.4	5/23/85
85-11	Completion of Phase II of "Control of Heavy Loads at Nuclear Power Plants" NUREG-0612	6/28/85
85-12	Implementation of TMI Action Item II.K.3.5, "Automatic Trip of Reactor Coolant Pumps"	6/28/85
85-13	Transmittal of NUREG-1154 Regarding the Davis Besse Loss of Main and Auxiliary Feedwater Event	8/5/85
84-14	Commercial Storage at Power Reactor Sites of Low Level Radioactive Waste not Generated by the Utility	8/1/85
85-15	Information Relating to the Deadlines for Compliance with 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants"	8/6/85