

AUG 21 1985

ENCLOSURE 1

NOTICE OF VIOLATION

Virginia Electric and Power Company
North Anna Units 1 and 2

Docket Nos. 50-338 and 50-339
License Nos. NPF-4 and NPF-7

The following violation was identified during an inspection conducted on July 8 - August 4, 1985. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Unit 1 and Unit 2 Technical Specifications (TS) 4.8.1.1.3a specify a number of surveillance requirements that are to be performed at least once per seven days. 1 and 2-PT-85, DC Distribution Systems, are the performance tests the licensee uses to satisfy the above requirements. Unit 1 and Unit 2 TS 4.0.2 require, in part, that each surveillance requirement be performed within the specified interval with a maximum allowable extension not to exceed 25 percent of the surveillance interval.

Contrary to the above, the surveillance intervals for 1 and 2-PT-85 were exceeded in that the tests were performed on July 9, 1985, and were not performed again until July 19, 1985.

This is a Severity Level V violation (Supplement 1) and applies to both Units.

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice a written statement or explanation in reply including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted, (3) the corrective steps which have been taken and the results achieved, (4) corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: AUG 21 1985

8509050012 850821
PDR ADOCK 05000338
G PDR