

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Zion, Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 2 9 5	PAGE (3) 1 OF 0 2
-----------------------------------	--------------------------------------	----------------------

TITLE (4) Actuation of Fire Protection Containment Isolation Valve
Due to Broken Control Air Line

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)	
0	7	3	1	8	5	0	1	6	1	0 5 0 0 0	
0	7	3	1	8	5	0	1	6		0 5 0 0 0	

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8. (Check one or more of the following) (11)										
	20.402(b)			20.405(c)			<input checked="" type="checkbox"/> 50.73(a)(2)(iv)			73.71(b)	
	20.405(a)(1)(i)			50.36(c)(1)			50.73(a)(2)(v)			73.71(c)	
	20.405(a)(1)(ii)			50.36(c)(2)			50.73(a)(2)(vii)			OTHER (Specify in Abstract below and in Text, NRC Form 366A)	
	20.405(a)(1)(iii)			50.73(a)(2)(i)			50.73(a)(2)(viii)(A)				
POWER LEVEL (10) 0 19 19	20.405(a)(1)(iv)			50.73(a)(2)(ii)			50.73(a)(2)(viii)(B)				
	20.405(a)(1)(v)			50.73(a)(2)(iii)			50.73(a)(2)(ix)				

LICENSEE CONTACT FOR THIS LER (12)								TELEPHONE NUMBER			
NAME <i>Stan Berczynski</i> Stan Berczynski								AREA CODE			
								3 1 2 7 4 6 - 2 0 8 4			

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC
X	KIP	1FCV-M1210		No					

SUPPLEMENTAL REPORT EXPECTED (14)				EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO						

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

On July 31, 1985 at 0600 hours the operator performing PT-300 (Containment Isolation Valves Operability Check) accidentally tripped over and broke off the control air line to the Fire Protection Containment Isolation Valve 1FCV-FP08. Since this valve is air-to-open, the valve failed closed as it should have. The closed position is the accident position for this valve.

The broken air line was repaired and the valve returned to its normal position. No further corrective action is required at this time.

8509050238 850830
PDR ADDCK 05000295
S PDR

TE22
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104
EXPIRES: 8/31/85

FACILITY NAME (1) Zion, Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 2 9 5 8 5 - 0 1 6 - 0 0	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
					0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On July 31, 1985 at 0600 hours the operator performing PT-300 (Containment Isolation Valves Operability Check) accidentally tripped over and broke off the control air line to the Fire Protection Containment Isolation Valve IFCV-FP08. Since this valve is air-to-open, the valve failed closed as it should have. The closed position is the accident position for this valve.

The broken air line was repaired later in the day and the valve returned to its normal position. There is no previous record of LERs or DVRs issued which document any similar failures of this valve. No further corrective action is required.



Commonwealth Edison

Zion Generating Station
101 Shiloh Blvd.
Zion, Illinois 60099
Telephone 312/746-2084

August 30, 1985

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

References: 10CFR50

Dear Sir:

The enclosed Licensee Event Report from Zion Generating Station is being transmitted to you in accordance with the requirements of 10CFR50.73(a)(2)(iv) which requires a 30 day written report when an event or condition results in manual or automatic actuation of any Engineered Safety Feature (ESF).

This report is number 85-016-00, Docket No. 50-295/DPR-39.

Very truly yours,

for

K. L. Graesser
Station Manager
Zion Generating Station

KLK/rmm

Enclosure: Licensee Event Report No. 85-016-00

Attachment

cc: J. G. Keppler, NRC Region III Administrator
M. Holzmer, NRC Resident Inspector
INPO Record Center
CECo Distribution List

IE22
11