

**GPU Nuclear**

100 Interpace Parkway
Parsippany, New Jersey 07054
201 263-6500
TELEX 136-482
Writer's Direct Dial Number:

August 30, 1985
5211-85-2142
RFW-0602

Office of Nuclear Reactor Regulation
Attn: John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Three Mile Island Nuclear Station Unit 1 (TMI)
Operating License No. DPR-50
Docket No. 50-289
EQ-Victoreen Monitors

On August 1, 1985 GPUN completed installation of the qualified cables and connectors to the high range radiation monitors (RMG-22/23) manufactured by Victoreen. These in-containment monitors are now environmentally qualified as shown in EQ file (EQ-T1-144) which is available in our central file. Therefore, our Justification of Interim Operation (J10-T1-84-9 Rev. 2) is considered cancelled.

Sincerely,

R. F. Wilson

Director Technical Functions

Reference: GPUN letters dated 3/25/85 (5211-85-2059)
NRC letter dated 3/29/85

RFW:gpa
2279f/001

cc: J. Thoma
R. Conte

8509060119 850830
PDR ADOCK 05000289
PDR

Aug 30
1/0