

PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

DIABLO CANYON POWER PLANT
P.O. Box 56 • Avila Beach, California 93424 • (805) 595-7351R.C. THORNBERRY
PLANT MANAGER

August 30, 1985

Mr. William Briam, Administrator
San Luis Obispo County
Administrative Office
County Government Center
San Luis Obispo, CA 93408

Dear Mr Briam:

Pursuant to NUREG-0654, Revision 1, Appendix 1, the following is a summary report concerning an Unusual Event at the Diablo Canyon Nuclear Power Plant site.

On August 29, 1985, Unit 2 experienced a "High Steam Flow coincident with Low Tavg" safety injection. The safety injection signal caused the Emergency Core Cooling System to initiate and discharge to the Reactor Coolant System.

An Unusual Event was declared by the Shift Foreman at 0537 PDT and emergency notifications were completed by 0613 PDT.

This event in no way affected the operability of the plant and no discharge of radioactive materials were made to the environment.

Sincerely,

Robert C. Thornberry
ROBERT C. THORNBERRY

RCT:jhr

8509060152 850830
PDR ADOCK 05000323
S PDR

cc Mr. William Medigovich, Director
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Mr. John J. Kearns
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Ms. Ann Vasquez
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Mr. John B. Martin, Administrator
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368

Mr. George Whiting, Sheriff
San Luis Obispo County
P. O. Box 32
San Luis Obispo, CA 93401

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Director, Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555