

INDIANA & MICHIGAN ELECTRIC COMPANY

**DONALD C. COOK NUCLEAR PLANT**  
P.O. Box 458, Bridgman, Michigan 49106  
(616) 465-5901

August 22, 1985

PRIORITY ROUTING

First		Second	
NA		HC	
CH		PC	
OP		SA	
CP		PL	
SS		PI	
LR		OT	
		SM	

FILE *has*

Mr. J.G. Keppler, Regional Administrator  
United States Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Operating License DPR-58/74  
Docket Nos. 50-315/50-316

Dear Mr. Keppler:

Pursuant to the requirements of Appendix B, Part II, Nonradiological, Environmental Protection Plan, Section 3.2, a copy of the report to the Michigan Water Resources Commission notifying them of the failure to take a once-per-week grab sample for pH in the Circulating Water System for the week of July 20, 1985 through July 27, 1985, is attached. This report is required by Amendment No. 54 to Facility Operating License No. DPR-58 and Amendment No. 40 to Facility Operating License No. DPR-74 dated May 6, 1982.

Sincerely,

W.G. Smith, Jr.  
Plant Manager


/bab

Attachment

cc: John E. Dolan  
M.P. Alexich  
R.F. Kroeger  
H.B. Brugger  
R.W. Jurgensen  
NRC Resident Inspector  
R.C. Callen, MPSC  
G. Charnoff, Esq.  
J.M. Hennigan  
H.R. Denton, NRC  
J.F. Stietzel  
Dottie Sherman, ANI Library  
INPO  
PNSRC  
A.A. Blind

8509060359 850822  
PDR ADOCK 05000315  
S PDR

~~IE24~~ IE23  
7/1  
AUG 26 1985



**INDIANA & MICHIGAN ELECTRIC COMPANY**

ONE SUMMIT SQUARE, P.O. BOX 60, FORT WAYNE, IN. 46801  
Telephone (219) 425-2111

August 13, 1985

RICHARD C. MENGE  
Vice President

Paul D. Zugger, Executive Secretary  
Michigan Water Resources Commission  
Stevens D. Mason Building, Box 30026  
Lansing, Michigan 48909

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant  
NPDES Permit No. MI 0005827  
Condenser Cooling Water

During an audit of monitoring requirements made on August 9, 1985, it was discovered that a once-per-week grab sample for pH in the circulating water system was not made. Both nuclear units were out of service and the Unit 2 circulating water system was operated only intermittently during the week of July 20 through July 27, 1985.

Since pH samples of 8.2 on July 17 and 7.9 on July 31 were recorded, there was no known operation which would lead to a pH excursion during the week in question.

Very truly yours,

Richard C. Menge  
Vice President

RCM/df

c: W. G. Smith

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge