



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

Doc 6

July 29, 1985

Aug + 2

PRIORITY ROUTING	
First	Second
RC	RC
STC	STC
HL	HL
OL	OL
OL	OL
FILE	<i>file</i>

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

In accordance with LaSalle County Station Unit 1 and Unit 2 Facility Operating License NPF-11 and NPF-18, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES noncompliance for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
G. J. Diederich
Station Manager
LaSalle County Station

GJD/FRL/SKS/kg

Enclosure

xc: NRC Resident Inspector
INPO - Records Center
US NRC Document Control Desk

8509090029 850729
PDR ADOCK 05000373
S PDR

AUG 5 1985

IE24
IE23
1/1

August 1, 1985

U. S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604


Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances which are listed on the attached table.

If there are any questions, please contact Steve Davis of my staff at (815) 357-6761, extension 487.


G. J. Diederich
Station Manager

GJD/FRL/SKD/sjc

xc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001(c) Wastewater Treatment System Effluent

PARAMETER AND PERMIT LIMIT: Oil and Grease, 20 ppm daily maximum
Oil and Grease, 15 ppm 30 day average

NONCOMPLIANCE, DATE, AND DURATION:

82 ppm Oil and Grease, 17JUN85, unknown
34 ppm Oil and Grease, 24JUN85, unknown
33 ppm Oil and Grease, 30-day average, 03JUL85, month of June

CAUSE OF NONCOMPLIANCE:

A large volume of oil entered the Wastewater Treatment System and overloaded it. The source of the oil and grease is unknown.

CORRECTIVE ACTION:

Attempts are being made to identify the source of oil and grease inputs into the Wastewater Treatment System.

The oil and grease was pumped out of the clarifiers and oil separator pits. The oil absorbent booms in the clearwell and effluent chamber were replaced.

Efforts are also being made to restore the polymer systems to an operable condition.

DATE RECOGNIZED AS A VIOLATION:

03JUL85

DATE INVESTIGATED:

05JUL85