

## NOTICE OF DEVIATION

Commonwealth Edison Company  
Quad Cities Station  
Cordova, Illinois

Docket Nos. 50-254; 50-265  
License Nos. DPR-29; DPR-30

During an NRC inspection conducted October 1 through November 6, 1996, a deviation of your actions committed to in Licensee Event Reports 50-254/92008 and 50-265/92007 was identified. In accordance with the "General Statement of Policy and Procedures for NRC Enforcement Actions," NUREG-1600, the deviation is listed below:

- A. Quad Cities Licensee Event Reports 50-254/92008 and 50-265/92007, dated April 8 and April 5, 1992, respectively, included a commitment to develop a procedure to trend and analyze residual heat removal (RHR) room cooler cooling water differential pressures.

Contrary to the above, on October 3, 1996, the inspectors identified that although a procedure to measure RHR room cooler cooling water differential pressures had been developed and implemented, a procedure to trend and analyze these differential pressures had not been developed or implemented.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, in writing within 30 days of the date of this Notice, (1) the reason for the deviation, or if contested, the basis of disputing the deviation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further deviations, and (4) the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois  
this 22 day of November 1996