

TABLE 3.3.4-2

REACTOR CORE ISOLATION COOLING SYSTEM ACTUATION INSTRUMENTATION

| <u>FUNCTIONAL UNITS</u>                           | <u>TRIP SETPOINT</u> | <u>ALLOWABLE<br/>VALUE</u> |
|---|----------------------|----------------------------|
| a. Reactor Vessel Water Level - Low Low (Level 2) | $\geq -55$ inches*   | $\geq -55$ inches*         |
| b. Condensate Storage Tank Level - Low            | $\geq 0$ inches**    | $\geq 0$ inches**          |
| c. Suppression Pool Water Level-High              | $\leq 151$ inches    | $\leq 151$ inches          |

\*See Bases Figure B 3/4 3-1

\*\* Equivalent to 10,000 gallons of water in the CST.

8509090152 850830  
PDR ADOCK 05000366  
P PDR